

Tank identification		Tank specification				Inventory					Certification requirement			
Tag number	Package number	Heated tank [Yes, No]	Operating temperature (Celsius)	Tank material	Pressurized tank (Yes, No)	Substance	Max. volume in permit application (m3)	CMR (Y/N)	ADR class	Applicable statute / regulation	Design code	Independent design assessment	Construction requirements	Certification / Installation requirement
11FB-01		Yes	40	SS316L	No	Barometric water (oil/fat/water)	30	N	non-ADR	No applicable statute / regulation	1. Single walled tank, and, 2. concrete floor, i.e. processing area	Design assesment by T.EN & Neste	No independent 3rd party monitoring / QCP by T.EN & Neste required	Validation by T.EN & Neste
12FB-01 Feed Tank		Yes	60	SS316L	No	BL2 (oil/fat)	230	N	non-ADR	NRB 2012 table 1.2, cvm I	1. Single walled tank, and 2. Liquid Resistant Layer between tank floor and soil,, i.e. concrete floor 3. curbed area note: richtlijn Bodembescherming atmosferische bovengrondse opslagtanks (Bobo).	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Verification by T.EN & Neste that permit requirements have been fulfilled
12FB-02 1st silo		No	ambient	CS	No	PTU2 Bleaching earth (solid)	200	N	non-ADR	No applicable statute / regulation	1. concrete floor, i.e. processing area	Design assesment by T.EN & Neste	No independent 3rd party monitoring / QCP by T.EN & Neste required	Validation by T.EN & Neste
12FB-04 silo		No	ambient	CS	No	PTU2 Filter Aid (Bleaching earth)	200	N	non-ADR	No applicable statute / regulation	1. concrete floor, i.e. processing area	Design assesment by T.EN & Neste	No independent 3rd party monitoring / QCP by T.EN & Neste required	Validation by T.EN & Neste
12FB-07		Yes	56	SS316L	No	Barometric water (water)	27	N	non-ADR	No applicable statute / regulation	1. Single walled tank, and, 2. concrete floor, i.e. processing area	Design assesment by T.EN & Neste	No independent 3rd party monitoring / QCP by T.EN & Neste required	Validation by T.EN & Neste
12FB-14		No	20	SS316L	No	Phosphoric acid	55	N	8	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
12FB-15		No	20	SS316L	No	Citric acid (50%)	55	N	non-ADR	NRB 2012 table 1.3, cvm I	1. Single walled tank; and 2. Liquid Resistant Layer between tank floor and soil, or drip tray.	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Verification by T.EN & Neste that permit requirements have been fulfilled
21FA-67		No	40	Alloy 625	Yes	SWS-afval (acid-base composition type of substance)	50	N	8	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
21FA-66A 21FA-66B		No	40	CS	Yes	Ammonia-water (25%) from SWS unit; ammonium hydroxide.	145	N	8	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
21FB-01		No	50	CS	No	Amine storage (MDEA)	200	N	non-ADR	NRB2012 table 1.2, cvm I	1. Single walled tank, and 2. Liquid Resistant Layer between tank floor and soil,, i.e. concrete floor 3. curbed area note: richtlijn Bodembescherming atmosferische bovengrondse opslagtanks (Bobo).	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Verification by T.EN & Neste that permit requirements have been fulfilled
40FB-20		No	40	CS	No	Bio-naphta	4,000	Y	3	PGS 29	EN-14015 Foundation of PGS29 storage tank to be liquid tight.	Design appraisal to be done by independent 3rd party: NL-CBIT	Witnessing of construction by NL-CBIT	- Tank: Installation certificate (declaration of conformity) to be issued by subcontractor; - Foundation: Declaration of conformity (certificate) to be issued by civil contractor; - Tank+Foundation+Protective Functions: Construction certificate (Nieuwbouw certificaat) to be issued by NL-CBIT.
40FB-18		No	30	LTCS	Yes	Bio-propane	2,500.0	N	2	PGS 19	PED 2014/68/EU WBDA 2016 BRL K901, NEN-EN 13636 NEN-EN-ISO 12944-5 of BRL-K790/03.	Design appraisal to be done by EU-CBI & DOC by manufacturer.	Witnessing of construction plaatsen, aansluiten & carcfaag aan de EU-CBI (Neste) tijd beschikbaar tbv deelinspectie KVI	BRL-K903 with main area A and B and sub-area 1 – soil resistance measurement, or by an accredited inspection company according to AS SIKB 6800 protocol
40FB-19		No	40	LTCS	Yes	Light naphta	2,500.0	N	2	PGS 19	PED 2014/68/EU WBDA 2016 BRL K901, NEN-EN 13636 NEN-EN-ISO 12944-5 of BRL-K790/03.	Design appraisal to be done by EU-CBI & DOC by manufacturer.	Witnessing of construction plaatsen, aansluiten & carcfaag aan de EU-CBI (Neste) tijd beschikbaar tbv deelinspectie KVI	BRL-K903 with main area A and B and sub-area 1 – soil resistance measurement, or by an accredited inspection company according to AS SIKB 6800 protocol
41FB-04 41FB-05		No	35	CS	No	Renewable Jet Fuel	2x 15.000	Y	3	PGS 29	EN-14015 Foundation of PGS29 storage tank to be liquid tight.	Design appraisal to be done by independent 3rd party: NL-CBIT	Witnessing of construction by NL-CBIT	- Tank: Installation certificate (declaration of conformity) to be issued by subcontractor; - Foundation: Declaration of conformity (certificate) to be issued by civil contractor; - Tank+Foundation+Protective Functions: Construction certificate (Nieuwbouw certificaat) to be issued by NL-CBIT.
41FB-06 41FB-07		No	40	CS	No	Renewable Diesel	2x 15.000	Y	3	PGS 29	EN-14015 Foundation of PGS29 storage tank to be liquid tight.	Design appraisal to be done by independent 3rd party: NL-CBIT	Witnessing of construction by NL-CBIT	- Tank: Installation certificate (declaration of conformity) to be issued by subcontractor; - Foundation: Declaration of conformity (certificate) to be issued by civil contractor; - Tank+Foundation+Protective Functions: Construction certificate (Nieuwbouw certificaat) to be issued by NL-CBIT.
41FB-08 41FB-09		No	35	CS	No	Renewable Diesel / Renewable Jet Fuel	2x 15.000	Y	3	PGS 29	EN-14015 Foundation of PGS29 storage tank to be liquid tight.	Design appraisal to be done by independent 3rd party: NL-CBIT	Witnessing of construction by NL-CBIT	- Tank: Installation certificate (declaration of conformity) to be issued by subcontractor; - Foundation: Declaration of conformity (certificate) to be issued by civil contractor; - Tank+Foundation+Protective Functions: Construction certificate (Nieuwbouw certificaat) to be issued by NL-CBIT.
42FB-01 42FB-02		Yes	70	CS + internal liner	No	Intermediate (Pretreated Feedstock)	2x 17.547	N	non-ADR	NRB2012 table 1.2, cvm I	1. Single walled tank; and 2. Liquid Resistant Layer between tank floor and soil note: richtlijn Bodembescherming atmosferische bovengrondse opslagtanks (Bobo).	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Verification by T.EN & Neste that permit requirements have been fulfilled
53FB-01		Yes	30	CS	No	Service water	155	N	non-ADR	No applicable statute / regulation	1. concrete floor, i.e. processing area	Design assesment by T.EN & Neste	No independent 3rd party monitoring / QCP by T.EN & Neste required	Validation by T.EN & Neste
57FB-01		No	55	CS	No	Hot oil	550	N	9	NRB 2012 table 1.2, cvm I	1. Single walled tank; and 2. Liquid Resistant Layer between tank floor and soil note: richtlijn Bodembescherming atmosferische bovengrondse opslagtanks (Bobo). EN-14015	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Verification by T.EN & Neste that permit requirements have been fulfilled

86FB-01 86FB-02		Yes	30	CS	No	Fire water	2x 8184	N	non-ADR	No applicable statute / regulation	1. concrete floor, i.e. processing area	Design assesment by T.EN & Neste	No independent 3rd party monitoring / QCP by T.EN & Neste required	Validation by T.EN & Neste
	21PK-01	No	15	SS304L	YES MAX 5,0 BARG ASME SECT. VIII DIV.1	Antistatic additive dosing package (Stadis 450)	2	Y	3	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
	21PK-03	to be decided	to be decided	to be decided	to be decided	Catalyst passivation chemical feed package (TBA)	to be decided	N	6.1	PGS15 NRB 2012 table 1.3, cvm I	1. Single walled tank; and 2. Liquid Resistant Layer between tank floor and soil, or drip tray.	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Verification by T.EN & Neste that permit requirements have been fulfilled
	21PK-14	ET10	AMBIENT	SS316L	YES MAX 0,2 BARG	Jet antioxidant additive dosing package	2	N	9	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
	21PK-19	NO	AMBIENT	SS304L	YES MAX 0,2 BARG	Jet antistatic additive dosing package	2	N	3	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
	53PK-03	ET10	AMBIENT	SS316L	YES MAX 0,2 BARG	Oxygen scavenger dosing package NALCO Elimn-Ox (or similar).	to be decided	N	non-ADR	NRB2012 table 1.2, cvm I	1. Single walled tank; and 2. Liquid Resistant Layer between tank floor and soil note: richtlijn Bodembescherming atmosferische bovengrondse opslag tanks (Bobo).	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Installation certificate to be issued by SIKB 7800 certified company
	53PK-04	to be decided	to be decided	to be decided	to be decided	pH neutralizer dosing package (NALCO 72310)	to be decided	N	8	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
21GA-25 (small feed pump) 21GA-52 (large feed pump)	No PK tag number	No	ambient	RID-ADR-IMDG UN portable tank T14	No	Dimethyldisulfide (DMDS)	2.6	N	3	PGS15 NRB 2012 table 1.3, cvm I	1. Single walled tank, and 2. Drip tray	Design assesment by T.EN & Neste	No independent 3rd party monitoring / QCP by T.EN & Neste required	Validation by T.EN & Neste
21FB-07		No	20	CS	No	Natronloog 20% (caustic soda 20%)	104	N	8	PGS 31	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
21FA-52		No	20	SS316L	No	Citroenzuur 50%	4	N	non-ADR	NRB 2012 table 1.3, cvm I	1. Single walled tank; and 2. Liquid Resistant Layer between tank floor and soil, or drip tray.	Verification by T.EN & Neste that permit requirements have been incorporated in the design	No independent 3rd party monitoring / no certified installation company required	Verification by T.EN & Neste that permit requirements have been fulfilled
86FA-01A 86FA-01B 86FA-01C diesel storage tank (fire fighting)		No	amb (inside) 5-20?	to be decided	No	Diesel	to be decided	Y	3	PGS30	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company
diesel storage tank (emergency generator)		to be decided	to be decided	to be decided	to be decided	Diesel	to be decided	Y	3	PGS30	BRL SIKB 7800	To be performed by SIKB 7800 certified company	To be installed by SIKB 7800 certified company	Installation certificate to be issued by SIKB 7800 certified company