NOTES

1. LOCATION OF THE O2 AND CO2 VESSEL & BOTTLE STATIONS SHALL BE AT 1 METER FROM THE FAÇADE, ACCORDING TO PGS-9 REGULATION.
2. FUEL TANK EMERGENCY POWER GENERATOR, 20 m3.
3. WASTE CONTAINER.

LEGEND

HOLDS

REV	DATE	DESCRIPTION	DRN.	DES.	CHKD.	APPR.
C	10.JAN.22	RE-ISSUED FOR CONCEPT	RKF	MFN	AST	WLN
B	21.DEC.21	RE-ISSUED FOR CONCEPT	THF	MFN	AST	WLN
A	26.NOV.21	ISSUED FOR CONCEPT	THF	MFN	AST	WLN

STATUS **CONCEPT**

CLIENT

janssen PHARMACEUTICAL COMPANIES OF Johnson & Johnson

DPS

THIS DRAWING IS THE PROPERTY OF DPS AND SHALL NOT BE USED, REPRODUCED OR DISCLOSED TO ANYONE WITHOUT THE PRIOR WRITTEN PERMISSION OF DPS AND SHALL BE RETURNED UPON REQUEST.

PROJECT **POLLUX**

TITLE
PLANTROOM LAYOUT
EL. +0.00m

PROJECT No.	A1 SCALE	DISCIPLINE		
A21LE037	N/A	HVAC		
CLIENT DRAWING NO.	DRAWING NO.		SHT	REV
N/A	A21LE037-HE-601		1/1	C