THIS DRAWING IS THE PROPERTY OF JANSSEN BIOLOGICS B.V. AND MAY NOT BE MADE PUBLIC OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF JANSSEN BIOLOGICS B.V.
EINSTEINWEG 101 2333 CG LEIDEN THE NETHERLANDS PHONE +31 (0) 71 5242444

NOTES

1) LUMINAIRES INDICATED 'E' ARE EMERGENCY LIGHT FITTINGS.

- LED SPATWATERDICHT 162 SERIES
- LED-PANEL "IDUN-S" 600 x 600mm
- RECESSED CEILING LED, IP44
- RECESSED CEILING LED, IP65
- LIGHTING MOTION/PRESENCE DETECTOR
- DAYLIGHT HARVESTING LIGHTING MOTION/PRESENCE DETECTOR
- A — ELECTRICAL SERVICES CEILING PANEL TYPE A: 6x230V, 2x400V
- B — ELECTRICAL SERVICES CEILING PANEL TYPE B: 4x230V, 1x400V
- S — MECHANICAL SERVICES CEILING PANEL TYPE S = (9 TOTAL)

HOLDS

OUT OF SCOPE

overige houtder- buiten beschouwing
Wall - out of scope

A	ISSUE FOR BOD	MMK 25.02.22	MBA 25.02.22	KDM 25.02.22	WLN 25.02.22
Rev.	DCRF No. CC# No.	Drawn By	Approval Change Owner	Approval System Owner	Approval Q.A.

janssen

TITLE: LIGHTING LAYOUT
PROJECT: POLLUX
SYSTEM: LIGHTING
DESCRIPTION: LEVEL 20

REF. FILES:	REPLACE DOC.:
A1.dwg	
SCALE: 1:150	SIZE: A1

DOC. No. L215-03-23-04 REV. A

REFERENCES : $REFS
PRINTED BY : $USER
DOCUMENT : $FILES
PLOT DATE : $DATE
PRINT TIME : $TIME