



NOTES

1. CEILING MOUNTED SOCKETS
2. 4 TIMES THE AMOUNT OF THE INDICATED DATA SOCKETS REQUIRED

- RJ45 DOUBLE SOCKET, DATA
- RJ45 DOUBLE SOCKET, TELEPHONE
- RJ45 DOUBLE SOCKET, VHP
- RJ45 SINGLE SOCKET, GxP
- RJ45 SINGLE SOCKET, DRS
- RJ45 SINGLE SOCKET, PAS
- CAMERA NETWORK CONNECTION
- RJ45 SINGLE SOCKET, ACCESS CONTROL PANEL
- RJ45 DOUBLE SOCKET, EMERGENCY LIGHTING SYSTEM

- WIFI WIFI POINT REDUNDANT WIRED AND DOUBLE PATCHED
- A TYPE A, CEILING PANEL; 2x DRS Profibus, 2x DRS, 6x GxP
- S TYPE S, CEILING PANEL; 2x GxP, 1x ModBus, 1x Profibus
- I TYPE I, CEILING PANEL; 6x DRS Profibus, 12x DRS

HOLDS

Rev.	ISSUE FOR BOD	MMK	MBA	KDM	WLN
	DCRF No. CC# No.	24.02.22	24.02.22	24.02.22	24.02.22
	Drawn By	Approval Change Owner	Approval System Owner	Approval Q.A.	
	TITLE: DATA LAYOUT				REF. FILES:
	PROJECT: POLLUX				A1.dwg
	SYSTEM: DATA				
	DESCRIPTION: LEVEL 00				
	SCALE: 1:150				SIZE: A1
	DOC. No. L220-04-23-01				REV. A