

Subject **Static Calculation**
Item **K3 storage tanks T-101 with volume 1.500 m³**
Clients reference -

Description

Vertical carbon steel storage tank with conical bottom, cylindrical shell and conical fixed-roof.
Design in accordance with EN 14015:2004.

Tank design data

Volume (gross)		1.526,814 m ³	
Volume (available)	100%	1.526,814 m ³	
Medium		Diesel/Fame/HVO/GTL	
Class PGS 29		3 -	
Design density		1,000 kg/dm ³	
Density test medium		1,000 kg/dm ³	
Shell diameter		12.000,000 mm	
Shell height		13.500,000 mm	
Fill height max	100%	13.500,000 mm	
Fill height min	0%	0,000 mm	
Slope cone roof		11,310 °	
Slope cone roof		0,197 rad	
Total height of tank top		14.711,207 mm	
Corrosion allowance bottom		0,000 mm	
Corrosion allowance shell		0,000 mm	
Corrosion allowance roof		0,000 mm	
Corrosion allowance rafters		0,000 mm (total)	
Insulation shell		0,000 mm	
Insulation roof		0,000 mm	
Working pressure min/max		ATM mbarg	
Working temperature min/max		AMB °C	
Design pressure		10,000 mbarg	
Design vacuum		5,000 mbarg	
Design temperature max		50,000 °C	
Design temperature min		-10,000 °C	
Test pressure		10,000 mbarg full of water	
Wind velocity		45,000 m/s	
LODMAT 30 years		-15,000 °C	
Required min.design temperature		-10,000 °C	
Pump filling rate		350,000 m ³ /h	HOLD: to be confirmed
Pump discharging rate		250,000 m ³ /h	HOLD: to be confirmed
Position of tank		outside	
Seismic zone	n.a.	0,000 g	

**TER GOEDKEURING
FOR APPROVAL**

Revision	Date	Description	Calc'd	Chk'd	Appr'd
-	29-05-20	First issue	PWK	JCB	PWK

Material Data

Roof, bottom and shell plates (material 1)

Material	S 235 JR
According to	EN 10025-93
Rm	340 MPa
Re	235 MPa
Re(0m)	235 MPa
E	192.000 MPa
E(0m)	192.000 MPa

Top curb profile and windgirder

Material	S 235 JR
According to	EN 10025
Rm	340 MPa
Re	235 MPa
Rm(0m)	340 MPa
Re(0m)	235 MPa
E	192.000 MPa
E(0m)	192.000 MPa

Tubelures tn ≤ 10 mm

Material	A 106 grade B
According to	ASTM A-106/SA-106
Rm	415 MPa
Re	240 MPa
Re(0m)	240 MPa

Reinforcing plates (1)

Material	S 235 JR
According to	EN 10025-93
Rm	340 MPa
Re	235 MPa
Re(0m)	235 MPa

Anchor bolts

Material	4.6
According to	NEN 914
Rm	390 MPa
Re	235 MPa

Roof, bottom and shell plates (material 2)

Material	-
According to	-
Rm	0 MPa
Re	0 MPa
Re(0m)	0 MPa
E	0 MPa
E(0m)	0 MPa

Roof supporting profiles

Material	S 235 JR
According to	EN 10025
Rm	340 MPa
Re	235 MPa
Rm(0m)	340 MPa
Re(0m)	235 MPa
E	192.000 MPa
E(0m)	192.000 MPa

Tubelures tn > 10 mm

Material	A 333 grade 6
According to	API / ASTM
Rm	415 MPa
Re	240 MPa
Re(0m)	240 MPa

Reinforcing plates (2)

Material	-
According to	-
Rm	0 MPa
Re	0 MPa
Re(0m)	0 MPa

Contents

<u>Calculation</u>	<u>according to</u>	<u>page</u>
Description/Design data		1
Material data		2
Conclusion		4
Cylindrical shell	EN 14015:2004	5
Bottom plating	EN 14015:2004	6
Conical roof without supporting	EN 14015:2004	7
Junction cone roof to shell	EN 14015:2004	8
Roof supporting structure	EN 1993 and Roark	9
Weight calculation		13
Overturning stability	EN 14015:2004 / RTOD D1201	14
Anchoring	EN 14015:2004 / RTOD D1302	15
Frangible roof joint anchored tank	BS 2654 F.4.2 / RTOD D1302	16
Openings in cylindrical shell	EN 14015:2004	17
Venting	BS 2654-1989 appendix F	18

Conclusion/summary

Shell	<u>course</u>	<u>height</u> [m]	<u>thickness</u> [mm]	<u>material</u>
	1	2,700	6,0	S 235 JR
	2	2,700	6,0	S 235 JR
	3	2,700	6,0	S 235 JR
	4	2,700	6,0	S 235 JR
	5	2,700	8,0	S 235 JR

shell plate thickness required as indicated for each ring
no secondary windgirder required
profile of secondary windgirder n.a.

Bottom annular ring	plate thickness	8,000 mm
	minimum size inside tank (la + lw)	582,558 mm
	minimum width	655,558 mm

Cone roof	supported cone roof	5,000 mm
	roof slope	11,310 °
	top curb angle	L 60 x 60 x 8
	for external loading roof supporting required	

Roof trusses	20	rafters	IPE 160	L=	4.946 mm
	centerring	UNP 180		D=	2.300 mm
	bracings				1
	cross bracings				0
	roof trusses are acceptable for external loading				
	centerring acceptable for forces of trusses				
	top curb is acceptable for forces of trusses				
	roof plating on supporting structure is acceptable for external loading				
	axial shell stress due to roof loads acceptable				

Anchors	quantity	14,000 pcs
	diameter	30,000 mm
	diameter of anchor circle	12,200 m

Shell nozzles	<u>mark</u>	<u>nominal</u>	<u>tube size</u> Dn [mm]	<u>reinforcing ring</u> tn [mm]	<u>Dv [mm]</u>	<u>t [mm]</u>
	N1, N2	DN 200	219,1	12,7	430,0	8,0
	M1	Ø 600	609,6	12,7	1.100,0	8,0

Frangible joint	calculation according BS 2654 appendix F.4.1. for anchored tanks
	roof to shell joint is not frangible

Venting ATM tank	nozzle diameter	219,100 mm
	nozzle wall thickness	8,200 mm
	number of nozzles	1,000 pcs
	Vent nozzle(s) are acceptable for vacuum and pressure	

Calculation
According to

Cylindrical Shell
EN 14015

D	=	diameter tank	=	12,000 m
H	=	cylindrical height of tank	=	13,500 m
c	=	corrosion allowance	=	0,000 mm
t;min up	=	min. specified shell thickness upper courses	=	6,000 mm
t;min low	=	min. specified shell thickness lowest course	=	8,000 mm
w	=	design density	=	1,000 kg/dm ³
wt	=	density test medium	=	1,000 kg/dm ³
p	=	pressure	=	10,000 mbarg
pt	=	test pressure	=	10,000 mbarg
Vw	=	design wind velocity	=	45,000 m/s
v	=	vacuum	=	5,000 mbar
G	=	extra loading	=	0,000 N
v;eq	=	vacuum equivalent to G	=	0,000 mbar
pv	=	design vacuum	=	5,000 mbar
η	=	joint efficiency factor	=	1,000 -
ec	=	formula shell plate thickness design [mm]		
et	=	formula shell plate thickness testing [mm]		
t;tol	=	plate thickness tolerance [mm]		
ts;min	=	minimum allowed gross design thickness [mm]		
ts	=	selected gross shell plate thickness [mm]		
t;net	=	net shell thickness [mm]		
h	=	height of course [m]		
Hc	=	fill height above lower of ring [m]		
He	=	equivalent stable height of each course with t;min [m]		
HE	=	equivalent stable full shell height at t;min [m]		
Hp	=	max. permitted spacing of rings on shell at t;min [m]		
K	=	a factor [-]		

Internal and external loading

material	=		1	S 235 JR	2	-
quality	=		working	test	working	test
Re(θm)	=	yield strength [MPa]	235,000	235,000	0,000	0,000
σ	=	design stress [MPa]	156,667	176,250	0,000	0,000
the smallest value of:	1) η x % x Re(θm)	[MPa]	156,667	176,250	0,000	0,000
	2) 260 MPa (see 7.1.1)	[MPa]	260,000	260,000	260,000	260,000

#	σ	σ	h	Hc	ec	et	t;tol	ts;min	ts	t;net	He
		[MPa]	[m]	[m]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[m]
1	1	156,67	2,700	2,700	0,939	0,835	0,400	6,000	6,000	6,000	2,700
2	1	156,67	2,700	5,400	1,952	1,735	0,400	6,000	6,000	6,000	2,700
3	1	156,67	2,700	8,100	2,966	2,636	0,400	6,000	6,000	6,000	2,700
4	1	156,67	2,700	10,800	3,979	3,537	0,400	6,000	6,000	6,000	2,700
5	1	156,67	2,700	13,500	4,993	4,438	0,500	8,000	8,000	8,000	1,315

K	=	9,392	Hp	=	19,923	HE	=	12,115
number of secondary wind girders				=	0			
minimum required profile of windgirder(s)				=	n.a.			

Conclusion: shell plate thickness required as indicated for each ring in column 'ts'
no secondary windgirder required

Calculation **Bottom Plating**
According to EN 14015

D	=	diameter tank	=	12,000 m
H	=	fill height liquid	=	13,500 m
e ₁	=	thickness first shell course (excl.corr.all.)	=	8,000 mm
c	=	corrosion allowance bottom	=	0,000 mm
l _w	=	lap annular plate to membrane	=	60,000 mm
l _d	=	stick out of bottom	=	65,000 mm

Thickness of annular plates or bottom under shell

e _a	=	minimum thickness [mm]	=	8,000 mm
the greater of:	1) 3 + e ₁ /3		=	5,667 mm
	2) minimum according code		=	6,000 mm
	3) project specification	##	=	8,000 mm
e _a + c	=	minimum thickness + corrosion allowance	=	8,000 mm

Design bottom thickness

tb	=	design bottom thickness	<u>working</u>	<u>test</u>
			8,000	8,000 mm

Minimum width annular plates (if applicable)

l _a	=	minimum width	=	522,558 mm
the greater of:	1) e _a x 240/√H		=	522,558 mm
	2) minium according code		=	500,000 mm
	3) project specification	##	=	0,000 mm
l _w + l _a + e ₁ + l _d		total minimum width of annular plate	=	655,558 mm

Liquid ring

material	=		1	S 235 JR	2	-	
quality	=		working	test	working	test	
σ	=	design stress	[MPa]	156,667	176,250	0,000	0,000
the smallest value of:	1) % x Re(θm)	[MPa]	156,667	176,250	0,000	0,000	
	2) 260 MPa (see poin	[MPa]	260,000	260,000	260,000	260,000	

material	=	1	Reb	=	<u>working</u>	<u>test</u>
tba	=				156,667	176,250 MPa
ws	=				8,000	8,000 mm
HT=hlr	=				1,000	1,000 g/ml
D	=				0,000	13,500 m
wl	=				12,000	12,000 m
the smallest value of:	1)				0,000	32,400 kN/m
	2)				0,032	39,023
m l _r	=				0,000	32,400
d	=				0,001	1.221,415 kN
wl _r	=				11,500	11,500 m
					0,250	0,250 m

Calculation According to **Conical Roof without supporting**
EN 14015

Θ	=	roof slope	=	0,197 rad
Θ	=	roof slope	=	11,310 °
c	=	corrosion allowance	=	0,000 mm
R	=	tank radius	=	6,000 m
tr;b	=	gross roof plate thickness	=	5,000 mm
tr;tol	=	tolerance	=	0,400 mm
tr;m	=	minimum roof plate thickness	=	5,000 mm
tr;n	=	net roof plate thickness	=	4,600 mm
R1	=	radius of curvature of roof	=	30,594 m
t;ins;shell	=	insulation thickness roof	=	0,000 mm
p	=	design pressure	=	10,000 mbarg
η	=	joint efficiency factor	=	0,350 -

Internal loading

<u>internal loading</u>					
material	=			1	2
quality	=			S 235 JR	-
Re(θm)	=	design stress	[MPa]	=	156,667 0,000
the smallest value of: 1) 0,67 x Re(θm)			[MPa]	=	156,667 0,000
2) 260 MPa (see point 7.1.1)			[MPa]	=	260,000 260,000
material	=	1	σ	=	156,667 MPa
tr	=	p x R1/(10 x σ x η)		=	0,558 mm

External loading

					new	corroded
c	=	corrosion allowance roof	[mm]	=	0,000	0,000
E	=	modulus of elasticity	[MPa]	=	192.000,000	192.000,000
pe	=	the sum of the following values	[Pa]	=	2.082,590	2.082,590
		1) external loading	[Pa]	=	1.200,000	1.200,000
		2) weight roof plates	[Pa]	=	382,590	382,590
		3) weight insulation	[Pa]	=	0,000	0,000
		4) negative design pressure	[Pa]	=	500,000	500,000
		5) other loading	[Pa]	=	0,000	0,000
tr	=	$40 \times R1 (10 \times pe/E)^{0,5}$	[mm]	=	12,745	12,745

Conclusion: roof thickness acceptable for pressure
for external loading roof supporting required

Calculation **Junction Cone Roof to Shell**
According to EN 14015

R	=	radius of shell	=	6,000 m
R1	=	radius of roof curvature	=	30,594 m
Θ	=	roof slope	=	0,197 rad
p	=	pressure	=	10,000 mbarg

Internal and external loading

σ_c	=	allowable compressive stress	=	120,000 MPa
σ	=	allowable tensile stress	=	156,667 MPa
the smallest value of: 1) roof plating				= 156,667 MPa
2) top curb				= 156,667 MPa
p_{calc}	=	calc.press. = $p - 0,77tr;n$	=	6,458 mbarg
$p_{e_{calc}}$	=	calc.external loading	=	21,132 mbarg
A	=	required compression area	=	1.213,957 mm ²
the greater value of: 1) see 10.5 table 18 L 60 x 60 x 8				= 903,000 mm ²
2) $50 \times p_{calc} \times R^2 / (\sigma_c \times \tan \Theta)$				= 484,347 mm ²
3) $50 \times p_{e_{calc}} \times R^2 / (\sigma \times \tan \Theta)$				= 1.213,957 mm ²

Compression area


				new	corroded
tr;n	=	net roof plate thickness	[mm]	4,600	4,600
t;net	=	net shell plate thickness of top course	[mm]	5,600	5,600
Wc	=	$0,6 (1000 \times R \times t;net)^{0,5}$	[mm]	109,982	109,982
Wh	=	$0,6 (1000 \times R1 \times tr;n)^{0,5}$	[mm]	225,086	225,086
A0	=	$(Wh + Wh_{outside}) \times tr;n$	[mm ²]	1.035,394	1.035,394
A1	=	$Wc \times t;net$	[mm ²]	615,898	615,898
A2	=	angle ring 5,42 L 60 x 60 x 8	[mm ²]	903,000	903,000
A3	=	insulation support	[mm ²]	0,000	0,000
Aw	=	available cross sectional area	[mm ²]	2.554,292	2.554,292

Conclusion:

The roof to shell junction is acceptable for pressure and external loading

Section modulus

b1	=	80,000 mm
b2	=	25,000 mm
b3	=	0,000 mm
e2	=	23,400 mm
$I_{z_{angle}}$	=	875.000,000 mm ⁴
L0	=	165,357 mm
L1	=	82,800 mm
L2	=	56,600 mm
L3	=	0,000 mm
X	=	107,003 mm
X0	=	58,355 mm
X1	=	24,203 mm
X2	=	50,403 mm
X3	=	107,003 mm
I_{z0}	=	7.729.050,252 mm ⁴
I_{z1}	=	362.384,350 mm ⁴
I_{z2}	=	3.169.009,350 mm ⁴
I_{z3}	=	0,000 mm ⁴
I_z	=	11.260.443,952 mm ⁴
e	=	168,712 mm
Wz	=	66.743,619 mm ³



Calculation **Roof Supporting Structure**
 Item Loadings
 According to EN 1993 and Roark

D	=	diameter tank	=	12,000 m
D2	=	diameter centerring	=	2,300 m
n	=	number of rafters	=	20,000

Design loadings

				new	corroded
Corrosion				0,000	0,000
l	=	[m]	=	4,850	4,850
pe	=	roof loading [Pa]	=	2.082,590	2.082,590
Θ	=	roof angle [rad]	=	0,197	0,197
q1	=	external loading [kN/m]	=	3,926	3,926
q2	=	dead load [kN/m]	=	0,158	0,158
F	=	extra loading	=	0,000	0,000
Q1	=	external loading per beam [kN]	=	11,777	11,777
Q2	=	dead load per beam [kN]	=	0,767	0,767
Q3	=	weight of centerring per r: [kN]	=	0,077	0,077
Q4	=	extra loading per beam	=	0,000	0,000
ls	=	length of rafters [l / cosΘ]	=	4,946	4,946
Mb1	=	0,128 x Q1 x l [kNm]	=	7,311	7,311
Mb2	=	Q2 x l / 8	=	0,465	0,465
M _{y,rep}	=	Mb1 + Mb2	=	7,776	7,776
Fh	=	(Q1 x D1/(6 x l) + Q2/2 + Q3 + Q4/n)/tanΘ	=	26,582	26,582
F _{rep}	=	Fh / cosΘ	=	27,108	27,108

Calculation **Roof Supporting Structure**
Item Roof Trusses
According to EN 1993

Steel section:		IPE 160			new	corroded
Corrosion			[mm]	=	0,00	0,00
A	=	cross section	[mm ²]	=	2.010,00	2.010,00
O	=	circumference profile	[mm]	=	623,00	
m	=	mass	[kg/m]	=	15,80	15,80
h	=	height	[mm]	=	160,00	160,00
b	=	width	[mm]	=	82,00	82,00
tf	=	thickness flange	[mm]	=	7,40	7,40
tw	=	thickness web	[mm]	=	5,00	5,00
I _y	=	second moment of area	[mm ⁴]	=	8.690.000,00	8.690.000,00
W _y	=	section modulus	[mm ³]	=	109.000,00	109.000,00
i _y	=	radius of gyration	[mm]	=	65,80	65,80
I _z	=	second moment of area	[mm ⁴]	=	683.000,00	683.000,00
W _z	=	section modulus	[mm ³]	=	16.700,00	16.700,00
i _z	=	radius of gyration	[mm]	=	18,40	18,40
l _{y;buc}	=	buckling length	[mm]	=	4.946,05	4.946,05
λ _{y;re}	=			=	0,84	0,84
ω _{y;buc}	=			=	0,70	0,70
n	=	number of bracings	[pcs]	=	1,00	1,00
l _{z;buc}	=	buckling length	[mm]	=	2.473,03	2.473,03
λ _{z;re}	=			=	1,50	1,50
ω _{z;buc}	=			=	0,37	0,37
f _{y;d}	=	yield strength	[MPa]	=	235,00	235,00
E _d	=	modulus of elasticity	[MPa]	=	192.000,00	192.000,00
λ _{re}	=	1,32 (l x h x f _{y;d} / (b x t _f x E _d)) ^{0,5}		=	1,18	1,18
ω _{kip}	=			=	0,54	0,54
N _{c;s;d}	=	γ _f x F _{rep} (γ _f = 1,2)	[kN]	=	32,53	32,53
M _{y;equ;s;d}	=	γ _f x M _{y;rep} (γ _f = 1,2)	[kNm]	=	9,33	9,33
N _{c;u;d}	=	f _{y;d} x A	[kN]	=	472,35	472,35
M _{y;u;d}	=	f _{y;d} x W _y	[kNm]	=	25,62	25,62

The following values shall be smaller than 1:

1) $1,1 \times N_{c;s;d} / (\omega_{y;buc} \times N_{p;l;d}) + 1,1 \times M_{y;equ;s;d} / (\omega_{kip} \times M_{y;u;d}) =$	0,85	0,85
2) $1,1 \times N_{c;s;d} / (\omega_{z;buc} \times N_{p;l;d}) + 1,1 \times M_{y;equ;s;d} / (\omega_{kip} \times M_{y;u;d}) =$	0,94	0,94

Conclusion: roof trusses are acceptable for external loading

Calculation **Roof Supporting Structure**
 Item Center Ring
 According to Roark

<u>Steel section:</u>		<u>UNP 180</u>		new	corroded
Corrosion			mm (total) =	0,00	0,00
A	=		[mm ²] =	2.800,00	2.800,00
O	=		[mm] =	611,00	
m	=			22,00	22,00
h	=		[mm] =	180,00	180,00
b	=		[mm] =	70,00	70,00
tf	=		[mm] =	11,00	11,00
tw	=		[mm] =	8,00	8,00
ez	=		[mm] =	19,20	19,20
Iz	=	available second moment	[mm ⁴] =	1.140.000,00	1.140.000,00
Wz	=		[mm ³] =	22.400,00	22.400,00
i _z	=		[mm] =	20,20	20,20
R	=	(D2 - 2 x ez) / 2	=	1.130,800	1.130,800

Strength according to Roark table 18 case 3

W	=	Fh	[N]	=	26.581,74	26.581,74
θ	=		[rad]	=	0,16	0,16
φ	=		[rad]	=	0,00	0,00
σ _a	=	allowable stress		=	156,67	156,67
E	=	modulus of elasticity		=	192.000,00	192.000,00
Mz	=	W x 2R sinθ/8		=	1.175.550,31	1.175.550,31
σ	=	Mz / Wz		=	52,48	52,48

Stability according to Roark table 34 case 8

p'	=	n x W / (2 x r x π)	=	74,83	74,83
I _{min}	=	p' x r ³ / (3 x E)	[mm ⁴] =	187.837,78	187.837,78

Conclusion: centerring acceptable for forces of trusses

Calculation **Roof Supporting Structure**
 Item Junction Roof to Shell
 According to Roark table 17 case 7

External loading

Iz	=	second moment of area	=	11.260.443,952 mm ⁴
Aw	=	cross section area of top curb	=	2.554,292 mm ²
Wz	=	section modulus	=	66.743,619 mm ³
σ_a	=	allowable stress	=	156,667 MPa
R	=	D/2 - X1	=	6.000,000 mm
W	=	Fh = horizontal	=	26.581,736 N
S	=	stress [MPa]		
θ	=	π / n	=	0,157 rad
M _A	=	W x R (1/sin θ - 1/ θ) / 2	=	2.093.748 Nmm
N _A	=	W / 2sin θ	=	84.961,322 N
S _A	=	M _A / Wz + N _A / Aw	=	64,632 MPa
M _B	=	W x R (1/ θ - cot θ) / 2	=	4.182.330 Nmm
N _B	=	W x cos θ / 2sin θ	=	83.915,309 N
S _B	=	M _B / Wz + N _B / Aw	=	95,515 MPa

Conclusion: top cub is acceptable for forces of trusses

Calculation **Roof Supporting Structure**
 Item Roof Plating on Trusses
 According to Roark table 26 case 6a

External loading

σ_a	=	0,67 x Re(θ m)	=	156,667 MPa	
pe	=	external roof loading	=	2.082,590 Pa	
θ	=	π / n	=	0,157 rad	
a	=	(D1 - D2)/2cos Θ	=	4.946,050 mm	
b	=	2 x (D/3) x tan θ	=	1.267,074 mm	
σ	=	stress [MPa]			
a/b	=	3,904	β	=	0,500
σ	=	$\beta \times pe \times b^2 / tr;n^2$	=	79.006 MPa	

Conclusion: roof plating on supporting structure is acceptable for external loading

Calculation **Roof Supporting Structure**
 Item Shell stability under axial loads
 According to EEMUA 159

t	=	nett shell thickness	=	6,000 mm
D	=	diameter of tank	=	12,000 m
R	=	nominal shell radius	=	6.000,000 mm
C	=	factor carbon steel standard	=	12.411,000 -
E _{0m} /E	=	correction factor (E _{0m} /210.000)	=	0,914 -
Wt	=	the total of dead load and live load on roof		
fa	=	calculated axial compression		
Fa	=	allowable axial compression		
Wt	=	the sum of the following values	=	2.249,510 Pa
		1) external loading	=	1.200,000 Pa
		2) weigth roof plates	=	382,590 Pa
		3) weigth roof supports	=	149,128 Pa
		4) weigth top curb	=	17,793 Pa
		5) weigth insulation	=	0,000 Pa
		6) negative design pressure	=	500,000 Pa
		7) other loading	=	0,000 Pa
q	=	maximum loading due to Wt	=	6,749 N/mm
fa	=	q / t	=	1,125 MPa
Fa	=	C x (t / R) x (E _{0m} /E)	=	11,347 MPa

Conclusion: axial shell stress due to roof loads acceptable

Calculation **Weight Calculation**
According to -

D	=	tankdiameter	=	12,000 m
H	=	cilindrical height	=	13,500 m
t;ins;shell	=	insulation thickness shell	=	0,000 mm
t;ins;roof	=	insulation thickness roof	=	0,000 mm
G	=	weight [N]		

<u>Subject</u>	<u>Working conditions</u>	<u>Test conditions</u>	<u>Total empty weight</u>	
Corrosion	corroded	new	new	
Bottom	5.680	5.680	70.704	N
Shell	249.234	249.234	249.234	N
Roof (cone)	44.127	44.127	44.127	N
Roof (dome)	0	0	0	N
Roof trusses	16.866	16.866	16.866	N
Radial folded rafters	0	0	0	N
Radial roof rafters	0	0	0	N
Connections	12.000	12.000	12.000	N
Spiral staircase	0	0	0	N
Caged ladder	0	0	0	N
Platform(s)	0	0	0	N
Handrailing(s)	4.335	4.335	4.335	N
Insulation shell	0	0	0	N
Insulation roof	0	0	0	N
Insulation support(s)	0	0	0	N
Top curb (cone)	2.012	2.012	2.012	N
Top curb (dome)	0	0	0	N
Primary windgirder	0	0	0	N
Secondary windgirder(0	0	0	N
Heating coil	0	0	0	N
Others				N
Total weight G	328.575	328.575	399.279	N

Total weight

Operation	Tank	399 kN	40,701 ton
	Insulation	0 kN	0,000 ton
	Medium	14.978 kN	1.526,814 ton
	Tank + medium	15.377 kN	1.567,515 ton
	Tank + insulation	399 kN	40,701 ton
	Tank + insulation + medium	15.377 kN	1.567,515 ton
Testing	Tank	399 kN	40,701 ton
	Testmedium	14.978 kN	1.526,814 ton
	Tank + testmedium	15.377 kN	1.567,515 ton

Calculation
According to

Overtuning Stability
EN 14015 and Stoomwezen 'Rules' D1201

D	=	tankdiameter	=	12,000 m
H	=	cylindrical height	=	13,500 m
Hw	=	height of tankwall	=	0,000 m
t;ins;shell	=	insulation thickness shell	=	0,000 mm
t;ins;roof	=	insulation thickness roof	=	0,000 mm
Cw;m	=	drag coefficient shell	=	0,700
Cw;s	=	drag coefficient steel structure	=	1,000
Cw;d	=	coefficient of friction by wind	=	0,040
hl min	=	minimum product liquid level	=	0,000 m
pw formule	=	wind pressure standard	=	1,288 kN/m ²
pw project	=	wind pressure alternative (NEN 6702)	=	0,000 kN/m ²

			<u>working</u>	<u>test</u>
p	=	internal pressure	1,000	1,000 kN/m ²
pw	=	wind pressure	1,288	0,966 kN/m ²
wlr	=	width of liquid ring	0,250	0,250 m
hlr	=	height of liquid ring	0,000	13,500 m
w	=	density medium	1,000	1,000 kg/dm ³

	<u>A</u>	<u>Ha</u>	<u>Mw</u>	<u>Mw;test</u>
	[m ²]	[m]	[kNm]	[kNm]
Shell	162,000	6,750	986,05	739,54
Ladder(s)/stair(s)	4,455	7,250	41,61	31,21
Handrail/structure(s)	5,520	14,000	99,55	74,66
Roof	115,337	14,700	87,36	65,52
Others	0,000	0,000	0,00	0,00

		<u>working</u>	<u>test</u>
Mw	=	wind moment (total)	1.214,58
Pr	=	int' press on roof plates	113,10
Pb	=	int' press. on annular plates	9,22
Gl	=	liquid ring	0,00
Gt	=	tank weight	328,57
F	=	loading on bottom-shell joint	4,78
			910,93 [kNm]
			113,10 [kN]
			9,22 [kN]
			1.221,42 [kN]
			328,57 [kN]
			-30,31 [kN/m]

Conclusion: anchors required for working conditions
no anchors required for test conditions

Calculation **Anchoring**
According to Stoomwezen 'Rules' D1302

D	=	diameter of tank	=	12,000 m
ts	=	thickness lowest course	=	0,000 mm
Dc	=	diameter of anchor circle	=	12,200 m
Da	=	diameter of anchors	=	30,000 mm
n	=	number of anchor bolts	=	14,000 pcs
As	=	cross section area of bolt	=	519,000 mm ²
σ_a	=	allowable stress (working conditions)	=	94,000 MPa
the smallest of:		1) 0,40 x Re	=	94,000 MPa
		2) 0,33 x Rm	=	128,700 MPa
$\sigma_{a;test}$	=	all. stress (test conditions) 0,85 x Re	=	199,750 MPa
σ	=	stress in bolt [MPa]		

Due to overturning

F_{anchor}	=	$4 M_w / (D_c \times n) - (G_t - P_r) / n$	13,053	0,000 kN
σ_{anchor}	=	$1000 \times F_{\text{anchor}} / A_s$	25,151	0,000 MPa

Conclusion: anchors acceptable for overturning

Calculation Frangible Roof to Shell joint anchored tank

According to BS 2654 appendix F.4.1

D	=	tankdiameter	=	12,000 m
R	=	radius of shell	=	6,000 m
f	=	fillet weld roof plates to top curb profile	=	5,000 mm
Θ	=	roof slope	=	0,197 rad
Aw	=	available compression area	=	2.554,292 mm ²
Sc	=	failure compressive stress	=	220,000 MPa
Dc	=	diameter of anchor circle	=	12,200 m
n	=	number of anchor bolts	=	14,000
As	=	cross section area of bolt	=	519,000 mm ²
σ_a	=	allowable stress (working conditions)	=	94,000 MPa
p	=	failure pressure [mbar]		

p	=	$A \times Sc \times \tan \Theta / (50 \times R^2)$	=	62,439 mbar
---	---	--	---	-------------

Weight calculation

c	=	corrosion allowance	[mm]	=	0,000	0,000
T	=	the sum of the following weights	[kN]	=	268,113	268,113
		1) shell	[kN]	=	249,234	249,234
		2) roof supporting (if supported by shell)	[kN]	=	16,866	16,866
		3) top curb profile	[kN]	=	2,012	2,012
		4) secondary windgirders	[kN]	=	0,000	0,000
		5) further	[kN]	=	0,000	0,000

Anchor check

c	=	corrosion allowance	[mm]	=	0,000	0,000
Mw	=	wind moment (total)	[kNm]	=	1.214,575	1.214,575
Pr	=	int' press on roof plates	[kN]	=	706,164	706,164
Gt	=	tank weight	[kN]	=	268,113	268,113
F _{anchor}	=	$4 Mw / (Dc \times n) - (Gt - Pr) / n$	[kN]	=	59,734	59,734
σ_{anchor}	=	$1000 \times F_{anchor} / As$	[Mpa]	=	115,094	115,094

Conclusie: roof to shell joint is not frangible

Calculation
According to

Openings in Cylindrical Shell
EN 14015

Dn	=	outside diameter nozzle [mm]
tn	=	nozzle thickness [mm]
c	=	corrosion allowance [mm]
tn;tol	=	nozzle tolerance [mm]
tn;net	=	net nozzle thickness [mm]
tm	=	minimum specified nozzle thickness [mm]
tl	=	net thickness internal [mm]
ln	=	calc. length internal [mm]
the smallest value of		1) $4 \times tn;net$ 2) internal length
An	=	$2 \times (tn;net - tm;net)(4 \times tn;net + t;net)$ [mm ²]
Al	=	$2 \times ln \times tl$ [mm ²]
Dv	=	outside diameter reinforcing pad [mm]
Dg	=	inside diameter reinforcing pad [mm]
tv	=	thickness reinforcing pad [mm]
tv;tol	=	tolerance reinforcing pad [mm]
tv;net	=	net thickness reinforcing pad [mm]
Av	=	$(Dv - Dg) tv;net$ [mm ²]
Dw	=	diameter hole in shell [mm]
t;net	=	net thickness shell [mm]
A	=	available area = $An + Al + Av$ [mm ²]
Amin	=	required area = $0,75 \times Dw \times t;net$ [mm ²]

Mark		N1, N2	M1
Nominal		DN 200	Ø 600
Dn	=	219,100	609,600
tn	=	12,700	12,700
c	=	0,000	0,000
tn;tol	=	1,588	1,588
tn;net	=	11,113	11,113
tm	=	12,500	12,500
tm;net	=	10,938	10,938
tl	=	11,113	11,113
ln	=	0,000	0,000
An	=	18,182	18,182
Al	=	0,000	0,000
Dv	=	430,000	1.100,000
Dg	=	219,100	609,600
tv	=	8,000	8,000
tv;tol	=	0,400	0,400
tv;net	=	7,600	7,600
Av	=	1.602,840	3.727,040
course	=	5,000	5,000
Dw	=	219,100	609,600
t;net	=	7,500	7,500
A	=	1.621,023	3.745,223
Amin	=	1.232,438	3.429,000

Calculation **Venting atmospherical tank**
According to BS 2654-1989 Appendix F

Nozzle data

De_{nozzle}	=	external diameter of nozzle	=	219,10 mm
t_{nozzle}	=	wall thickness of nozzle	=	8,20 mm
Di_{nozzle}	=	internal diameter of nozzle	=	202,70 mm
A_{nozzle}	=	cross section of venting nozzle	=	0,0323 m ²
n	=	number of venting nozzles	=	1,00 pcs
v_{max}	=	maximum allowable velocity in nozzle	=	10,00 m/s

Vacuum

$\phi_{\text{pump;out}}$	=	pump capacity by emptying	=	250,00 m ³ /h
V	=	volume of tank	=	1526,81 m ³
A	=	surface area	=	622,04 m ²
$\phi_{\text{req pumping}}$	=	required capacity for emptying	=	250,00 m ³ /h
$\phi_{\text{req temp.}}$	=	required capacity for temp.decr.	=	274,83 m ³ /h
$\phi_{\text{req total}}$	=	total required venting capacity	=	524,83 m ³ /h
v_{nozzle}	=	velocity of air in nozzle	=	4,52 m/s

Pressure

$\phi_{\text{pump;in}}$	=	pump capacity by filling	=	350,00 m ³ /h
		flash point lower than 38°C ?	=	no
$\phi_{\text{req pumping}}$	=	required capacity for filling	=	374,50 m ³ /h
$\phi_{\text{req total}}$	=	total required venting capacity	=	539,40 m ³ /h
v_{nozzle}	=	velocity of air in nozzle		4,65 m/s

Conclusion: Vent nozzle(s) are acceptable for vacuum and pressure