

1. SEE SH.1
2. THIS DRAWING IS VALID ONLY FOR SUBCONTRACTOR SYSTEM AND FINISHING DETAILED DESIGN, MATERIAL SELECTION AND FOR BUILDING PERMIT.
3. THE STAIRCASES SHALL BE PROVIDED OF EMERGENCY LIGHTING.
4. FOR APPLICABLE FIRE AND SMOKE CLAUSES PLEASE REFER TO THE "INTEGRAAL PLAN BRANDBEVEILIGHEID".
5. IN-ROOM DETECTION SYSTEMS SHALL BE EQUIPPED WITH AN ACOUSTIC AND OPTICAL SIGNALLING SYSTEM.
6. POSITION OF FIRE HYDRANTS IN GENERAL SITE SHALL BE CHECKED.

LEGEN	
TEKENSYMBOL	omschrijving
	Vluchtweide aanduiding conform NEN 8088, deren uitvoering als vluchtroute
	Noodaandring, deren uitvoering als vluchtroute
	Brandwerendheid ten minste 30 minuten WBOBO
	Brandwerendheid ten minste 60 minuten WBOBO
	Brandwerendheid ten minste 120 minuten WBOBO
	Brandwerendheid en zelfsluitende deur, 30 minuten WBOBO
	Brandwerendheid en zelfsluitende deur, 60 minuten WBOBO
	Brandwerendheid en zelfsluitende deur, 120 minuten WBOBO
	Scheidingsplaat, scheidingsplaat van 30 meter conform NEN-EN 671 blad 1 im 3
	Draagbaar blauwbladd (sproei schuim)
	Draagbaar blauwbladd op wielen (sproei schuim)
	Handbrandmelder
	Brandalarmbellen (rood)
	Brandalarm claxon
	Vlamdetector uitsluit type
	Rook afzuigkap
	Bezettingsbrandmelder
	Ruimte voorzien van automatische brandmelders
	Ruimte voorzien van automatische brandmelders met laagst mogelijke detectatie
	Brandverwijzing
	Vluchtroute



REFERENCE DRAWINGS

					Mario Calpin	Download File
					Download File	Download File
B	05/08/2021	ISSUED FOR LOCAL AUTHORITIES	P.FIORELLO	E. GERARDINI APPR M.CALPINI	V.COLONE/ MIANCOTI	
A	24/06/2021	ISSUED FOR FEED (DEFINITION PHASE)	S.TRUDEN	M.CALPINI	V.COLONE/ MIANCOTI	
REV	DATE	DESCRIPTION	PREP	CKD	APPR/AUTH	



NESTE

GENERAL DRAWINGS FOR PTU STRUCTURE EMERGENCY ESCAPE ROUTE AND FIRE PROTECTION LAYOUT

NESTE Drawing No

CAD Model	
-----------	--

TECHNIP ITALY S.p.A. - 00148 ROMA - Viale Castello della Magliana, 68

