

Daglichtberekening 18107 type A t/m E 22-05-2023

Woning type A

			Kozijnmerk	ε	CLTA	Ad:i	α	β	Cb:i	Cu:i	Ae:i				
	Woonkamer/keuken	52,6m²	10x B 1100x1915mm	90°	1	11,3	20°	0	0,80	1	9,04				
			C 1100x1915mm	90°	1	1,8	20°	0	0,80	1	1,44				
Verblijfsgebied 01			VG-01 52,6m² (10%) 5,26m²								10,48	voldoet			
	Slaapkamer 1	12,2m²	2x B 1100x1915mm	90°	1	2,3	20°	0	0,80	1	1,81	voldoet			
Verblijfsgebied 02			VG-02 tot = 12,2m² (10%) 1,22m²								1,81	voldoet			
	Slaapkamer 2	7,3m²	D 1100x1290mm	90°	1	0,8	20°	0	0,80	1	0,64	0,17	CK04	550x980	dakraam
	Slaapkamer 3	7,3m²	D 1100x1290mm	90°	1	0,8	20°	0	0,80	1	0,64	0,17	CK04	550x980	dakraam
Verblijfsgebied 03			VG-03 15,1m² (10%) 1,51m²								1,28	0,34	1,62	voldoet	

Woning type-B

			Kozijnmerk	ε	CLTA	Ad:i	α	β	Cb:i	Cu:i	Ae:i				
	Woonkamer/keuken	58,2m²	9x B 1100x1915mm	90°	1	10,1	20°	0	0,80	1	8,08				
			C 1990x2513mm	90°	1	1,8	20°	0	0,80	1	1,44				
Verblijfsgebied 01			VG-01 58,2m² (10%) 5,82m²								9,52	voldoet			
	Slaapkamer 1	12,2m²	B 1100x1915mm	90°	1	1,1	20°	0	0,80	1	0,90	0,17	CK04	550x980	dakraam
												0,17	CK04	550x980	dakraam
Verblijfsgebied 02			VG-02 tot = 12,2m² (10%) 1,22m²								0,90	0,34	1,24		
	Slaapkamer 2	7,6m²	D 1100x1915mm	90°	1	1,1	20°	0	0,80	1	0,90				
	Slaapkamer 3	7,6m²	D 1100x1915mm	90°	1	1,1	20°	0	0,80	1	0,90				
Verblijfsgebied 03			VG-03 15,4m² (10%) 1,54m²								1,81	voldoet			

Woning type-C

			Kozijnmerk	ε	CLTA	Ad:i	α	β	Cb:i	Cu:i	Ae:i				
	Woonkamer/keuken	46,0m²	5x B 1100x1915mm	90°	1	5,6	20°	0	0,80	1	4,48				
			C 1990x2513mm	90°	1	1,8	20°	0	0,80	1	1,44				
			H 1110x1580mm	90°	1	0,9	20°	0	0,80	1	0,73				
Verblijfsgebied 01			VG-01 46,0m² (10%) 4,60m²								6,65	voldoet			
	Slaapkamer 1	12,6m²	2x D 1100x1290mm	90°	1	1,6	20°	0	0,80	1	1,26				
Verblijfsgebied 01			VG-03 12,6m² (10%) 1,26m²								1,26	voldoet			
	Slaapkamer 2	6,0m²	E 1160x3000mm	90°	1	1,9	20°	0	0,80	1	1,50				
Verblijfsgebied 02			VG-03 6,0m² (10%) 0,60m²								1,50	voldoet			
	Slaapkamer 3	8,4m²	2x B 1100x1915mm	90°	1	2,3	20°	0	0,80	1	1,81				
Verblijfsgebied 03			VG-03 8,4m² (10%) 0,84m²								1,81	voldoet			

Woning type-C'

			Kozijnmerk	ε	CLTA	Ad:i	α	β	Cb:i	Cu:i	Ae:i				
	Woonkamer/keuken	46,0m²	2x B 1100x1915mm	90°	1	2,2	20°	0	0,80	1	1,76				
			2x G 1700x1915mm	90°	1	3,8	20°	0	0,80	1	3,04				
			C 1990x2513mm	90°	1	1,8	20°	0	0,80	1	1,44				
			H 1110x1580mm	90°	1	0,9	20°	0	0,80	1	0,73				

Verblijfsgebied 01			VG-01 46,0m² (10%) 4,60m²								6,97	voldoet			
	Slaapkamer 1	12,6m²	2x D 1100x1290mm	90°	1	1,6	20°	0	0,80	1	1,26				
Verblijfsgebied 01			VG-03 12,6m² (10%) 1,26m²								1,26	voldoet			
	Slaapkamer 2	6,0m²	E2 1160x3000mm	90°	1	1,9	20°	0	0,80	1	1,50				
Verblijfsgebied 02			VG-03 6,0m² (10%) 0,60m²								1,50	voldoet			
	Slaapkamer 3	8,4m²	2x B 1100x1915mm	90°	1	2,3	20°	0	0,80	1	1,81				
Verblijfsgebied 03			VG-03 8,4m² (10%) 0,84m²								1,81	voldoet			

Woning type-D

			Kozijnmerk	ε	CLTA	Ad:i	α	β	Cb:i	Cu:i	Ae:i				
	Woonkamer/keuken	41,5m²	3x B 1220x1850mm	90°	1	3,9	20°	0	0,80	1	3,12				
			C 1990x2513mm	90°	1	1,8	20°	0	0,80	1	1,44				
Verblijfsgebied 01			VG-01 41,5m² (10%) 4,15m²								4,56	voldoet			
	Slaapkamer 1	15,0m²	E 3000x1460mm	90°	1	2,6	20°	0	0,80	1	2,05				
Verblijfsgebied 02			VG-02 tot = 15,0m² (10%) 1,50m²								2,05	voldoet			
	Slaapkamer 2	8,2m²	E3 1600x1460mm	90°	1	1,2	20°	0	0,80	1	0,96				
	Slaapkamer 3	6,5m²	E3 1600x1460mm	90°	1	1,2	20°	0	0,80	1	0,96				
Verblijfsgebied 03			VG-03 15,3m² (10%) 1,53m²								1,92	voldoet			

Woning type E

			Kozijnmerk	ε	CLTA	Ad:i	α	β	Cb:i	Cu:i	Ae:i				
	Woonkamer/keuken	38,9m²	2x B1 1100x1850mm	90°	1	2,2	20°	0	0,80	1	1,76				
			C1 1890x2513mm	90°	1	1,6	20°	0	0,80	1	1,28				
			I 2000x1400mm	90°	1	1,7	20°	0	0,80	1	1,36				
			J 2600x2610mm	90°	1	5,6	20°	0	0,80	1	4,48				
Verblijfsgebied 01			VG-01 38,9m² (10%) 3,89m²								8,88	voldoet			
	Slaapkamer 1	13,2m²	K 1300x2610mm	90°	1	2,7	20°	0	0,80	1	2,16				
			E4 1800x1330mm	90°	1	1,4	20°	0	0,80	1	1,12				
	Slaapkamer 2	10,5m²	K 1300x2610mm	90°	1	2,7	20°	0	0,80	1	2,16				
			Dakraam PK10 942x1600	50°	1	1,1	20°	0	0,98	1	1,08				
	Slaapkamer 3	5,0m²	Dakraam PK10 942x1600	50°	1	1,1	20°	0	0,98	1	1,08				
Verblijfsgebied 02			VG-03 28,7m² (10%) 2,87m²								7,60	voldoet			

Woning type F

			Kozijnmerk	ε	CLTA	Ad:i	α	β	Cb:i	Cu:i	Ae:i				
	Woonkamer/keuken	38,9m²	2x B1 1100x1850mm	90°	1	2,2	20°	0	0,80	1	1,76				
			C1 1890x2513mm	90°	1	1,6	20°	0	0,80	1	1,28				
			I 2000x1400mm	90°	1	1,7	20°	0	0,80	1	1,36				
Verblijfsgebied 01			VG-01 38,9m² (10%) 3,89m²								4,40	voldoet			
	Slaapkamer 1	13,2m²	E4 1800x1330mm	90°	1	1,4	20°	0	0,80	1	1,12				
	Slaapkamer 2	10,5m²	Dakraam PK10 942x1600	50°	1	1,1	20°	0	0,98	1	1,08				
	Slaapkamer 3	5,0m²	Dakraam PK10 942x1600	50°	1	1,1	20°	0	0,98	1	1,08				
Verblijfsgebied 02			VG-03 28,7m² (10%) 2,87m²								3,28	voldoet			