

## TEST REPORT

### ANSI/CAN/UL 9540A:2019

#### Test Method for Evaluating Thermal Runaway Fire Propagation in Battery Energy Storage Systems

Report Reference No..... : 241016030GZU-002

Tested by .....  
(name + signature) ..... : Engineer .....

Approved by .....  
(name + signature) ..... : Reviewer .....

Total number of pages..... : 65

Date of issue..... : 11 April 2025

Testing Laboratory..... : Intertek Testing Services Shenzhen Ltd. Zengcheng Branch

Address..... : C2-1, Heping Xu, Yongning Street, Zengcheng District, Guangzhou, China

Testing location/ procedure ..... : Lab test

Testing location/ address..... : Intertek Testing Services Shenzhen Ltd. Zengcheng Branch  
C2-1, Heping Xu, Yongning Street, Zengcheng District, Guangzhou, China

Applicant's name ..... : Sigenergy Technology Co., Ltd.

Address..... : No. 175 Weizhan Road, Lingang New Area, China(Shanghai) Pilot Free  
Trade Zone, Shanghai, P.R.China

Test specification:

Standard ..... : ANSI/CAN/UL 9540A:2019 (Fourth Edition) + UL CRD's

Test procedure..... : Unit level test (clause 9.1-9.8)

Non-standard test method..... : N/A

Test Report Form No..... : ANSI/CAN/UL 9540A\_Unit

Test Report Form(s) Originator ..... : Intertek

Master TRF ..... : 2022-01

This publication may be reproduced in whole or in part for non-commercial purpose as long as Intertek is acknowledged as copyright owner and source of the material. Intertek takes no responsibility and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

Test item description ..... : SigenStack Energy Storage System

Trade Mark ..... : Sigenergy

Manufacturer..... : Sigenergy Technology Co., Ltd.  
No. 175 Weizhan Road, Lingang New Area, China(Shanghai) Pilot Free  
Trade Zone, Shanghai, P.R.China

Model/Type reference..... : Refer to page 13 for details

Ratings..... : Refer to page 14-18 for details

#### **General disclaimer:**

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**List of attachments:**

Attachment 1 – Photos  
Attachment 2 – Sample preparation  
Attachment 3 – Arrangement of the unit  
Attachment 4 – Thermal runaway preparation  
Attachment 5 – Observations and records  
Attachment 6 – Temperature measurements  
Attachment 7 – Heat flux measurements  
Attachment 8 – Chemical heat release rate measurement  
Attachment 9 – Convective heat release rate measurement  
Attachment 10 – Gas generation measurement  
Attachment 11 – Smoke release rate measurement  
Attachment 12 – Equipment list

Test video 20250315-1.mp4 to 20250315-9.mp4 were provided in addition to this test report.

**Summary of testing:**

Thermal Runaway Propagation.....: 3 cells vented and thermal runaway due to thermal runaway propagation in the initiating module 2.  
7 cells in the initiating module 2 vented but no thermal runaway.  
No thermal runaway propagation from initiating module to other modules in initiating unit.

Maximum Target BESS Temperature (°C) .....: 27.3°C  
Maximum Wall Surface Temperature (°C) .....: 39.5°C  
Maximum Heat Flux on target wall surfaces (kW/m<sup>2</sup>) ..: N/A  
Maximum Heat Flux on target BESS units (kW/m<sup>2</sup>) ....: N/A  
Peak Chemical Heat Release Rate (kW) .....: 9.88kW  
Peak Convective Heat Release Rate (kW) .....: 0kW  
Peak Smoke Heat Release Rate (m<sup>2</sup>/s) .....: 0.1987m<sup>2</sup>/s  
Total Smoke Release (m<sup>2</sup>) .....: 109.4m<sup>2</sup>  
Maximum Heat Flux on Egress Path (kW/m<sup>2</sup>) .....: 0.029kW/m<sup>2</sup>  
External Flaming from BESS .....: Not observed  
Flying debris or explosive discharge of gases .....: Not observed  
Sparks, electrical arcs, or other electrical events .....: Not observed  
Re-ignitions .....: Not observed

**Conclusion:**

The performance criteria of the unit level test as indicated in 9.8 of UL 9540A 4th edition has been met.

Installation level testing in Section 10 is not required because the performance conditions outlined in Table 9.1 are met during the unit level test.

**Possible test case verdicts:**

- test case does not apply to the test object.....: N/A
- test object was not evaluated for the requirement.....: N/A
- test object does meet the requirement.....: Pass (P)
- test object does not meet the requirement .....: Fail (F)

**Testing:**

Date of receipt of test items .....: 11 March 2025

Date(s) of performance of tests .....: 13 March 2025 to 17 March 2025

**General remarks:**

"(see Attachment #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

The tests results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

List of test equipment must be kept on file and available for review.

Additional test data and/or information provided in the attachments to this report.

Throughout this report a  comma /  point is used as the decimal separator.

Determination of the test results includes consideration of measurement uncertainty from the test equipment and methods.

**General product information:**

This test unit is a non-residential indoor floor mounted and outdoor ground mounted energy storage system. It also can cover non-residential open garage and non-residential rooftop use energy storage system.

**Product information:****Cell information**

|   |   |
|---|---|
| Manufacturer.....                         | REPT BATTERO Energy Co., Ltd.   |
| Model name .....                          | CB75  |
| Chemistry.....                            | LiFePO <sub>4</sub>   |
| Physical configuration.....               | Prismatic   |
| Dimension (W*H*T) .....                   | 174(±2) mm x 204.4(±2) mm x 71.7(±2) mm                                     |
| Weight.....                               | 5.78±0.3 kg   |
| Nominal voltage .....                     | 3.2V  |
| Rated capacity .....                      | 314Ah   |
| If the cell compliance with UL 1973 ..... | Compliance / Report No. CN23RW5E 001<br>Certification No. CU 72303136 01-02 |

**Standard charge method**

|                            |        |
|----------------------------|--------|
| Charge current.....        | 157 A  |
| End of charge voltage..... | 3.65 V |
| Cut off current .....      | 15.7 A |


**Standard discharge method**

|                                |       |
|--------------------------------|-------|
| Discharge current .....        | 157 A |
| End of discharge voltage ..... | 2.5 V |

**Test result from cell level 9540A test report**

|  |  |
|--|--|
| Cell level test report .....                         | Issued by TUV Rheinland (Shanghai) Co., Ltd.<br>Report No.: CN234568 001 |
| Average cell venting temperature .....               | 127.9 °C   |
| Average cell thermal runaway onset temperature ..... | 179.8 °C   |
| Gas composition .....                                | See cell level UL9540A test report                                       |
| LFL at ambient temperature .....                     | 7.7% at 24°C±2°C and 101±3kPa  |
| LFL cell venting temperature .....                   | 7.1% at 127.9°C±2°C and 101±3kPa   |
| Burning velocity .....                               | 0.688 m/s  |
| P <sub>max</sub> .....                               | 0.798 Mpa  |

**Diagram of cell with overall dimension**



**Module information**

Manufacturer.....: Sigenergy Technology Co., Ltd.  
 Model name.....: SigenStack BAT 12.0

**Physical configuration**

Enclosure material.....: Metal  
 Dimension (L\*W\*H) .....: 770 mm x 363 mm x 300 mm  
 Weight.....: 105.5 kg  
 Cells in series/parallel: .....: 1P12S  
 Total number of cells: .....: 12 cells  
 Cooling method .....: Electric fan  
 Separation between cells .....: 4.2 mm by silicone foam

**Electrical rating**

Rated energy .....: 12060 Wh  
 Nominal voltage.....: 38.4V

**Standard charge method**

Charge power.....: 6.0288kW  
 End of charge voltage.....: 42.6V

**Standard discharge method**


Discharge power .....: 6.0288kW  
 End of discharge voltage.....: 34.8V  
 If the module compliance with UL 1973 .....: NA

**Test result from module level 9540A test report**


|   |                         |
|---|-------------------------|
| Module level test report .....  | 241016030GZU-001        |
| Peak chemical heat release rate HRR (kW) .....                            | 19.11kW                 |
| Peak smoke release rate SRR (m <sup>2</sup> /s) .....                     | 9.291 m <sup>2</sup> /s |
| Total smoke release TSR (m <sup>2</sup> ) .....                           | 2286.05m <sup>2</sup>   |
| Total Hydrocarbons (equivalent to CH <sub>4</sub> , measured by FID)..... | 617.16 L                |
| Module weight loss (kg).....  | 8.5kg                   |

**Diagram of module with overall dimension**


Unit: mm




Front view




Left view




Right view



Top view





Bottom view


**Contents (main components) of the module**


| PACK |                        |    |                           |    |                     |
|------|------------------------|----|---------------------------|----|---------------------|
| 1    | Upper Cover            | 8  | Rear Cover                | 15 | Lower Floating Plug |
| 2    | Cell Connection System | 9  | Transition Board          |    |                     |
| 3    | Battery Cell           | 10 | Battery Management System |    |                     |
| 4    | Heating Film           | 11 | Right Cover               |    |                     |
| 5    | Housing                | 12 | Outlet Guard              |    |                     |
| 6    | Air Duct Guard         | 13 | Fan Guard                 |    |                     |
| 7    | Upper Floating Plug    | 14 | Fan                       |    |                     |


**Layout of the module contents**




**Module structure diagram and cell series and/or parallel configuration (with cell numbered)**



**Photo of the module**





| Unit information                                |  |
|---|--|
| Manufacturer:                                   | Sigenergy Technology Co., Ltd.   |
| Model:  | SigenStack M2-0.5C-20/241.15 kWh, SigenStack M2-0.5C-21/253.21 kWh, SigenStack M2-0.5C-22/265.27 kWh, SigenStack M2-0.5C-23/277.32 kWh, SigenStack M2-0.5C-24/289.38 kWh, SigenStack M2-0.5C-25/301.44 kWh, SigenStack M2-0.5C-BST-4/48.23 kWh, SigenStack M2-0.5C-BST-5/60.29 kWh, SigenStack M2-0.5C-BST-6/72.35 kWh, SigenStack M2-0.5C-BST-7/84.4 kWh, SigenStack M2-0.5C-BST-8/96.46 kWh, SigenStack M2-0.5C-BST-9/108.52 kWh, SigenStack M2-0.5C-BST-10/120.58 kWh, SigenStack M2-0.5C-BST-11/132.63 kWh, SigenStack M2-0.5C-BST-12/144.69 kWh, SigenStack M2-0.5C-BST-13/156.75 kWh, SigenStack M2-0.5C-BST-14/168.81 kWh, SigenStack M2-0.5C-BST-15/180.86 kWh, SigenStack M2-0.5C-BST-16/192.92 kWh, SigenStack M2-0.5C-BST-17/204.98 kWh, SigenStack M2-0.5C-BST-18/217.04 kWh, SigenStack M2-0.5C-BST-19/229.09 kWh, SigenStack M2-0.5C-BST-20/241.15 kWh, SigenStack M2-0.5C-BST-21/253.21 kWh, SigenStack M2-0.5C-BST-22/265.27 kWh, SigenStack M2-0.5C-BST-23/277.32 kWh, SigenStack M2-0.5C-BST-24/289.38 kWh, SigenStack M2-0.5C-BST-25/301.44 kWh, SigenStack M2-1C-BST-4/48.23 kWh, SigenStack M2-1C-BST-5/60.29 kWh, SigenStack M2-1C-BST-6/72.35 kWh, SigenStack M2-1C-BST-7/84.4 kWh, SigenStack M2-1C-BST-8/96.46 kWh, SigenStack M2-1C-BST-9/108.52 kWh, SigenStack M2-1C-BST-10/120.58 kWh, SigenStack M2-1C-BST-11/132.63 kWh, SigenStack M2-1C-BST-12/144.69 kWh, SigenStack M2-1C-BST-13/156.75 kWh, SigenStack M2-1C-BST-14/168.81 kWh, SigenStack M2-1C-BST-15/180.86 kWh, SigenStack M2-1C-BST-16/192.92 kWh, SigenStack M2-1C-BST-17/204.98 kWh, SigenStack M2-1C-BST-18/217.04 kWh, SigenStack M2-1C-BST-19/229.09 kWh, SigenStack M2-1C-BST-20/241.15 kWh, SigenStack M2-1C-BST-21/253.21 kWh, SigenStack M2-0.5C-BST-22/265.27 kWh, SigenStack M2-0.5C-BST-23/277.32 kWh, SigenStack M2-0.5C-BST-24/289.38 kWh, SigenStack M2-0.5C-BST-25/301.44 kWh |
| Test model:                                     | SigenStack M2-0.5C-BST-25/301.44 kWh   |
| Type of system:                                 | <input type="checkbox"/> Battery System (BS) <input checked="" type="checkbox"/> Battery ESS   |
| Intended use location:                          | <input type="checkbox"/> Residential <input checked="" type="checkbox"/> Non-residential<br><input checked="" type="checkbox"/> Non-residential rooftop<br><input checked="" type="checkbox"/> Non-residential open garage use   |
| Type of installation:                           | <input checked="" type="checkbox"/> Indoor floor mounted <input checked="" type="checkbox"/> Outdoor ground mounted<br><input type="checkbox"/> Indoor wall mounted <input type="checkbox"/> Outdoor wall mounted  |
| Enclosure material:                             | <input checked="" type="checkbox"/> Metal <input checked="" type="checkbox"/> Non-metal<br><input type="checkbox"/> Open rack  |
| Spacing between modules:                        | 0mm  |
| Integrated fire protection system in the unit   | No fire detection and suppression system installed for the unit level test   |
| If the unit compliance with UL 1973 or UL 9540: | N/A  |

| <b>Electrical rating</b>                     |                                     |                                      |                                      |                                      |                                      |
|--|-------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|
| Model:                                       | SigenStack M2-0.5C-BST-4/48.23 kWh  | SigenStack M2-0.5C-BST-5/60.29 kWh   | SigenStack M2-0.5C-BST-6/72.35 kWh   | SigenStack M2-0.5C-BST-7/84.4 kWh    | SigenStack M2-0.5C-BST-8/96.46 kWh   |
| Rated capacity (Ah):                         | 314                                 | 314                                  | 314                                  | 314                                  | 314                                  |
| Rated energy (kWh):                          | 48.23                               | 60.29                                | 72.35                                | 84.4                                 | 96.46                                |
| Nominal voltage (V):                         | 153.6                               | 192                                  | 230.4                                | 268.8                                | 307.2                                |
| Weight(kg):                                  | 500                                 | 605.5                                | 711                                  | 816.5                                | 922                                  |
| Module series and/or parallel configuration: | 4S1P                                | 5S1P                                 | 6S1P                                 | 7S1P                                 | 8S1P                                 |
| Total number of cells:                       | 48                                  | 60                                   | 72                                   | 84                                   | 96                                   |
| <b>Standard charge method:</b>               |                                     |                                      |                                      |                                      |                                      |
| Charge power (kW):                           | 24.1152                             | 30.144                               | 36.1728                              | 42.2016                              | 48.2304                              |
| End of charge voltage (V):                   | 170.4                               | 213                                  | 255.6                                | 298.2                                | 340.8                                |
| <b>Standard discharge method:</b>            |                                     |                                      |                                      |                                      |                                      |
| Discharge power (kW):                        | 24.1152                             | 30.144                               | 36.1728                              | 42.2016                              | 48.2304                              |
| End of discharge voltage (V):                | 139.2                               | 174                                  | 208.8                                | 243.6                                | 278.4                                |
|  |                                     |                                      |                                      |                                      |                                      |
| Model:                                       | SigenStack M2-0.5C-BST-9/108.52 kWh | SigenStack M2-0.5C-BST-10/120.58 kWh | SigenStack M2-0.5C-BST-11/132.63 kWh | SigenStack M2-0.5C-BST-12/144.69 kWh | SigenStack M2-0.5C-BST-13/156.75 kWh |
| Rated capacity (Ah):                         | 314                                 | 314                                  | 314                                  | 314                                  | 314                                  |
| Rated energy (kWh):                          | 108.52                              | 120.58                               | 132.63                               | 144.69                               | 156.75                               |
| Nominal voltage (V):                         | 345.6                               | 384                                  | 422.4                                | 460.8                                | 499.2                                |
| Weight(kg):                                  | 1027.5                              | 1133                                 | 1238.5                               | 1344                                 | 1449.5                               |
| Module series and/or parallel configuration: | 9S1P                                | 10S1P                                | 11S1P                                | 12S1P                                | 13S1P                                |
| Total number of cells:                       | 108                                 | 120                                  | 132                                  | 144                                  | 156                                  |
| <b>Standard charge method:</b>               |                                     |                                      |                                      |                                      |                                      |
| Charge power (kW):                           | 54.2592                             | 60.288                               | 66.3168                              | 72.3456                              | 78.3744                              |
| End of charge voltage (V):                   | 383.4                               | 426                                  | 468.6                                | 511.2                                | 553.8                                |
| <b>Standard discharge method:</b>            |                                     |                                      |                                      |                                      |                                      |
| Discharge power (kW):                        | 54.2592                             | 60.288                               | 66.3168                              | 72.3456                              | 78.3744                              |
| End of discharge voltage (V):                | 313.2                               | 348                                  | 382.8                                | 417.6                                | 452.4                                |

| Model:                                       | SigenStack M2-0.5C-BST-14/168.81 kWh | SigenStack M2-0.5C-BST-15/180.86 kWh | SigenStack M2-0.5C-BST-16/192.92 kWh | SigenStack M2-0.5C-BST-17/204.98 kWh | SigenStack M2-0.5C-BST-18/217.04 kWh |
|--|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|
| Rated capacity (Ah):                         | 314                                  | 314                                  | 314                                  | 314                                  | 314                                  |
| Rated energy (kWh):                          | 168.81                               | 180.86                               | 192.92                               | 204.98                               | 217.04                               |
| Nominal voltage (V):                         | 537.6                                | 576                                  | 614.4                                | 652.8                                | 691.2                                |
| Weight(kg):                                  | 1555                                 | 1660.5                               | 1766                                 | 1871.5                               | 1977                                 |
| Module series and/or parallel configuration: | 14S1P                                | 15S1P                                | 16S1P                                | 17S1P                                | 18S1P                                |
| Total number of cells:                       | 168                                  | 180                                  | 192                                  | 204                                  | 216                                  |
| <b>Standard charge method:</b>               |                                      |                                      |                                      |                                      |                                      |
| Charge power (kW):                           | 84.4032                              | 90.432                               | 96.4608                              | 102.4896                             | 108.5184                             |
| End of charge voltage (V):                   | 596.4                                | 639                                  | 681.6                                | 724.2                                | 766.8                                |
| <b>Standard discharge method:</b>            |                                      |                                      |                                      |                                      |                                      |
| Discharge power (kW):                        | 84.4032                              | 90.432                               | 96.4608                              | 102.4896                             | 108.5184                             |
| End of discharge voltage (V):                | 487.2                                | 522                                  | 556.8                                | 591.6                                | 626.4                                |

| Model:                                       | SigenStack M2-0.5C-BST-19/229.09 kWh | SigenStack M2-0.5C-BST-20/241.15 kWh | SigenStack M2-0.5C-BST-21/253.21 kWh | SigenStack M2-0.5C-BST-22/265.27 kWh | SigenStack M2-0.5C-BST-23/277.32 kWh |
|--|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|
| Rated capacity (Ah):                         | 314                                  | 314                                  | 314                                  | 314                                  | 314                                  |
| Rated energy (kWh):                          | 229.09                               | 241.15                               | 253.21                               | 265.27                               | 277.32                               |
| Nominal voltage (V):                         | 729.6                                | 768                                  | 806.4                                | 844.8                                | 883.2                                |
| Weight(kg):                                  | 2082.5                               | 2188                                 | 2293.5                               | 2399                                 | 2504.5                               |
| Module series and/or parallel configuration: | 19S1P                                | 20S1P                                | 21S1P                                | 22S1P                                | 23S1P                                |
| Total number of cells:                       | 228                                  | 240                                  | 252                                  | 264                                  | 276                                  |
| <b>Standard charge method:</b>               |                                      |                                      |                                      |                                      |                                      |
| Charge power (kW):                           | 114.5472                             | 120.576                              | 125                                  | 125                                  | 125                                  |
| End of charge voltage (V):                   | 809.4                                | 852                                  | 894.6                                | 937.2                                | 979.8                                |
| <b>Standard discharge method:</b>            |                                      |                                      |                                      |                                      |                                      |
| Discharge power (kW):                        | 114.5472                             | 120.576                              | 125                                  | 125                                  | 125                                  |
| End of discharge voltage (V):                | 661.2                                | 696                                  | 730.8                                | 765.6                                | 800.4                                |

| Model:                                       | SigenStack M2-0.5C-BST-24/289.38 kWh | SigenStack M2-0.5C-BST-25/301.44 kWh | SigenStack M2-0.5C-20/241.15 kWh | SigenStack M2-0.5C-21/253.21 kWh | SigenStack M2-0.5C-22/265.27 kWh |
|--|--------------------------------------|--------------------------------------|----------------------------------|----------------------------------|----------------------------------|
| Rated capacity (Ah):                         | 314                                  | 314                                  | 314                              | 314                              | 314                              |
| Rated energy (kWh):                          | 289.38                               | 301.44                               | 241.15                           | 253.21                           | 265.27                           |
| Nominal voltage (V):                         | 921.6                                | 960                                  | 768                              | 806.4                            | 844.8                            |
| Weight(kg):                                  | 2610                                 | 2715.5                               | 2188                             | 2293.5                           | 2399                             |
| Module series and/or parallel configuration: | 24S1P                                | 25S1P                                | 20S1P                            | 21S1P                            | 22S1P                            |
| Total number of cells:                       | 288                                  | 300                                  | 240                              | 252                              | 264                              |
| <b>Standard charge method:</b>               |                                      |                                      |                                  |                                  |                                  |
| Charge power (kW):                           | 125                                  | 125                                  | 120.576                          | 125                              | 125                              |
| End of charge voltage (V):                   | 1022.4                               | 1065                                 | 852                              | 894.6                            | 937.2                            |
| <b>Standard discharge method:</b>            |                                      |                                      |                                  |                                  |                                  |
| Discharge power (kW):                        | 125                                  | 125                                  | 120.576                          | 125                              | 125                              |
| End of discharge voltage (V):                | 835.2                                | 870                                  | 696                              | 730.8                            | 765.6                            |


| Model:                                       | SigenStack M2-0.5C-23/277.32 kWh | SigenStack M2-0.5C-24/289.38 kWh | SigenStack M2-0.5C-25/301.44 kWh | SigenStack M2-1C-BST-4/48.23 kWh | SigenStack M2-1C-BST-5/60.29 kWh |
|--|----------------------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|
| Rated capacity (Ah):                         | 314                              | 314                              | 314                              | 314                              | 314                              |
| Rated energy (kWh):                          | 277.32                           | 289.38                           | 301.44                           | 48.23                            | 60.29                            |
| Nominal voltage (V):                         | 883.2                            | 921.6                            | 960                              | 153.6                            | 192                              |
| Weight(kg):                                  | 2504.5                           | 2610                             | 2715.5                           | 500                              | 605.5                            |
| Module series and/or parallel configuration: | 23S1P                            | 24S1P                            | 25S1P                            | 4S1P                             | 5S1P                             |
| Total number of cells:                       | 276                              | 288                              | 300                              | 48                               | 60                               |
| <b>Standard charge method:</b>               |                                  |                                  |                                  |                                  |                                  |
| Charge power (kW):                           | 125                              | 125                              | 125                              | 48.23                            | 60.29                            |
| End of charge voltage (V):                   | 979.8                            | 1022.4                           | 1065                             | 170.4                            | 213                              |
| <b>Standard discharge method:</b>            |                                  |                                  |                                  |                                  |                                  |
| Discharge power (kW):                        | 125                              | 125                              | 125                              | 48.23                            | 60.29                            |
| End of discharge voltage (V):                | 800.4                            | 835.2                            | 870                              | 139.2                            | 174                              |


| Model:                                       | SigenStack M2-1C-BST-11/132.63 kWh | SigenStack M2-1C-BST-12/144.69 kWh | SigenStack M2-1C-BST-13/156.75 kWh | SigenStack M2-1C-BST-14/168.81 kWh | SigenStack M2-1C-BST-15/180.86 kWh |
|--|------------------------------------|------------------------------------|------------------------------------|------------------------------------|------------------------------------|
| Rated capacity (Ah):                         | 314                                | 314                                | 314                                | 314                                | 314                                |
| Rated energy (kWh):                          | 132.63                             | 144.69                             | 156.75                             | 168.81                             | 180.86                             |
| Nominal voltage (V):                         | 422.4                              | 460.8                              | 499.2                              | 537.6                              | 576                                |
| Weight(kg):                                  | 1238.5                             | 1344                               | 1449.5                             | 1555                               | 1660.5                             |
| Module series and/or parallel configuration: | 11S1P                              | 12S1P                              | 13S1P                              | 14S1P                              | 15S1P                              |
| Total number of cells:                       | 132                                | 144                                | 156                                | 168                                | 180                                |
| <b>Standard charge method:</b>               |                                    |                                    |                                    |                                    |                                    |
| Charge power (kW):                           | 125                                | 125                                | 125                                | 125                                | 125                                |
| End of charge voltage (V):                   | 468.6                              | 511.2                              | 553.8                              | 596.4                              | 639                                |
| <b>Standard discharge method:</b>            |                                    |                                    |                                    |                                    |                                    |
| Discharge power (kW):                        | 125                                | 125                                | 125                                | 125                                | 125                                |
| End of discharge voltage (V):                | 382.8                              | 417.6                              | 452.4                              | 487.2                              | 522                                |

| Model:                                       | SigenStack M2-1C-BST-6/72.35 kWh | SigenStack M2-1C-BST-7/84.4 kWh | SigenStack M2-1C-BST-8/96.46 kWh | SigenStack M2-1C-BST-9/108.52 kWh | SigenStack M2-1C-BST-10/120.58 kWh |
|--|----------------------------------|---------------------------------|----------------------------------|-----------------------------------|------------------------------------|
| Rated capacity (Ah):                         | 314                              | 314                             | 314                              | 314                               | 314                                |
| Rated energy (kWh):                          | 72.35                            | 84.4                            | 96.46                            | 108.52                            | 120.58                             |
| Nominal voltage (V):                         | 230.4                            | 268.8                           | 307.2                            | 345.6                             | 384                                |
| Weight(kg):                                  | 711                              | 816.5                           | 922                              | 1027.5                            | 1133                               |
| Module series and/or parallel configuration: | 6S1P                             | 7S1P                            | 8S1P                             | 9S1P                              | 10S1P                              |
| Total number of cells:                       | 72                               | 84                              | 96                               | 108                               | 120                                |
| <b>Standard charge method:</b>               |                                  |                                 |                                  |                                   |                                    |
| Charge power (kW):                           | 72.35                            | 84.4                            | 96.46                            | 108.52                            | 120.58                             |
| End of charge voltage (V):                   | 255.6                            | 298.2                           | 340.8                            | 383.4                             | 426                                |
| <b>Standard discharge method:</b>            |                                  |                                 |                                  |                                   |                                    |
| Discharge power (kW):                        | 72.35                            | 84.4                            | 96.46                            | 108.52                            | 120.58                             |
| End of discharge voltage (V):                | 208.8                            | 243.6                           | 278.4                            | 313.2                             | 348                                |

| Model:                                       | SigenStack M2-1C-BST-16/192.92 kWh | SigenStack M2-1C-BST-17/204.98 kWh | SigenStack M2-1C-BST-18/217.04 kWh | SigenStack M2-1C-BST-19/229.09 kWh | SigenStack M2-1C-BST-20/241.15 kWh |
|--|------------------------------------|------------------------------------|------------------------------------|------------------------------------|------------------------------------|
| Rated capacity (Ah):                         | 314                                | 314                                | 314                                | 314                                | 314                                |
| Rated energy (kWh):                          | 192.92                             | 204.98                             | 217.04                             | 229.09                             | 241.15                             |
| Nominal voltage (V):                         | 614.4                              | 652.8                              | 691.2                              | 729.6                              | 768                                |
| Weight(kg):                                  | 1766                               | 1871.5                             | 1977                               | 2082.5                             | 2188                               |
| Module series and/or parallel configuration: | 16S1P                              | 17S1P                              | 18S1P                              | 19S1P                              | 20S1P                              |
| Total number of cells:                       | 192                                | 204                                | 216                                | 228                                | 240                                |
| <b>Standard charge method:</b>               |                                    |                                    |                                    |                                    |                                    |
| Charge power (kW):                           | 125                                | 125                                | 125                                | 125                                | 125                                |
| End of charge voltage (V):                   | 681.6                              | 724.2                              | 766.8                              | 809.4                              | 852                                |
| <b>Standard discharge method:</b>            |                                    |                                    |                                    |                                    |                                    |
| Discharge power (kW):                        | 125                                | 125                                | 125                                | 125                                | 125                                |
| End of discharge voltage (V):                | 556.8                              | 591.6                              | 626.4                              | 661.2                              | 696                                |

| Model:                                       | SigenStack M2-1C-BST-21/253.21 kWh | SigenStack M2-0.5C-BST-22/265.27 kWh | SigenStack M2-1C-BST-23/277.32 kWh | SigenStack M2-1C-BST-24/289.38 kWh | SigenStack M2-1C-BST-25/301.44 kWh |
|--|------------------------------------|--------------------------------------|------------------------------------|------------------------------------|------------------------------------|
| Rated capacity (Ah):                         | 314                                | 314                                  | 314                                | 314                                | 314                                |
| Rated energy (kWh):                          | 253.21                             | 265.27                               | 277.32                             | 289.38                             | 301.44                             |
| Nominal voltage (V):                         | 806.4                              | 844.8                                | 883.2                              | 921.6                              | 960                                |
| Weight(kg):                                  | 2293.5                             | 2399                                 | 2504.5                             | 2610                               | 2715.5                             |
| Module series and/or parallel configuration: | 21S1P                              | 22S1P                                | 23S1P                              | 24S1P                              | 25S1P                              |
| Total number of cells:                       | 252                                | 264                                  | 276                                | 288                                | 300                                |
| <b>Standard charge method:</b>               |                                    |                                      |                                    |                                    |                                    |
| Charge power (kW):                           | 125                                | 125                                  | 125                                | 125                                | 125                                |
| End of charge voltage (V):                   | 894.6                              | 937.2                                | 979.8                              | 1022.4                             | 1065                               |
| <b>Standard discharge method:</b>            |                                    |                                      |                                    |                                    |                                    |
| Discharge power (kW):                        | 125                                | 125                                  | 125                                | 125                                | 125                                |
| End of discharge voltage (V):                | 730.8                              | 765.6                                | 800.4                              | 835.2                              | 870                                |


**Diagram of unit with overall dimension (Unit: mm)**



**Contents (main components) of the module**
**For battery module:**


| PACK |                        |    |                           |    |                     |
|------|------------------------|----|---------------------------|----|---------------------|
| 1    | Upper Cover            | 8  | Rear Cover                | 15 | Lower Floating Plug |
| 2    | Cell Connection System | 9  | Transition Board          |    |                     |
| 3    | Battery Cell           | 10 | Battery Management System |    |                     |
| 4    | Heating Film           | 11 | Right Cover               |    |                     |
| 5    | Housing                | 12 | Outlet Guard              |    |                     |
| 6    | Air Duct Guard         | 13 | Fan Guard                 |    |                     |
| 7    | Upper Floating Plug    | 14 | Fan                       |    |                     |

**For base support:**

SigenStack Base MAIN



**For BCU:**


| SigenStack BC M2-1C-BST / SigenStack BC M2-0.5C-BST |                    |                      |
|---|--------------------|----------------------|
| 1 Control Board                                     | 8 Fan Component    | 15 Fuse              |
| 2 Intermediate Partition Board                      | 9 Air Duct Cover   | 16 DT Terminal       |
| 3 Power Board                                       | 10 Cover           | 17 Wiring Cover      |
| 4 Inductor  | 11 Capacitor Board | 18 Light Guide Plate |
| 5 Housing   | 12 Relay           | 19 Fan Guide Rail    |
| 6 Switch  | 13 EMI Board       | 20 Fan               |
| 7 Display Board                                     | 14 Hall Board      | 21 Floating Plug     |

| SigenStack BC M2-0.5C          |                    |                      |
|--------------------------------|--------------------|----------------------|
| 1 Control Board                | 8 Fan Component    | 15 Fuse              |
| 2 Intermediate Partition Board | 9 Air Duct Cover   | 16 DT Terminal       |
| 3 Power Board                  | 10 Cover           | 17 Wiring Cover      |
| 4 Fuse                         | 11 Capacitor Board | 18 Light Guide Plate |
| 5 Housing                      | 12 Relay           | 19 Fan Guide Rail    |
| 6 Switch                       | 13 EMI Board       | 20 Fan               |
| 7 Display Board                | 14 Hall Board      | 21 Floating Plug     |

**Photo of the unit**



| ANSI/CAN/UL 9540A |  |  |         |
|-------------------|--|--|---------|
| Clause            | Requirement – Test   | Result - Remark  | Verdict |
| <b>5</b>          | <b>Construction – General</b>  |  |         |
| <b>5.1</b>        | <b>Cell</b>  |  |         |
| 5.1.1             | The cell info associated with the BESS includes:   |  |         |
|                   | • cell chemistry (e.g. NMC, LFP);  | LiFePO <sub>4</sub>  | P       |
|                   | • the physical format of the cell;   | Prismatic  | P       |
|                   | • the cell electrical rating in capacity and nominal voltage;                                  | 3.2V, 314Ah  | P       |
|                   | • the overall dimensions of the cell, and weight.  | See page 4-5   | P       |
| 5.1.2             | The cells associated with the BESS comply with ANSI/CAN/UL 1973 or not.                        | Certificate provided.  | P       |
| 5.1.3             | Further details included in the cell level test report.  |  | P       |
| <b>5.2</b>        | <b>Module</b>  |  |         |
| 5.2.1             | The modules info associated with the BESS includes:  |  |         |
|                   | • the generic enclosure material;  | Metal  | P       |
|                   | • the general layout of the module contents;   | See page 6-10  | P       |
|                   | • the electrical configuration of the cells in the modules and the modules in the BESS.        | 1P12S  | P       |
| 5.2.2             | The modules associated with the BESS comply with UL 1973 or not.                               |  | N/A     |
| 5.2.3             | Further details included in the module level test report.                                      | Refer to 8.3   | P       |
| <b>5.3</b>        | <b>Battery energy storage system unit</b>  |  |         |
| 5.3.1             | The BESS unit info includes:   |  |         |
|                   | • the units comply with UL 9540 or not;  |  | N/A     |
|                   | • the manufacturer and model number;   |  | P       |
|                   | • electrical ratings;  |  | P       |
|                   | • energy capacity of all BESS.   |  | P       |
| 5.3.2             | For BESS units, which UL 9540 compliance cannot be determined, to include:                     |  |         |
|                   | • the number of modules in the BESS;   | 4~25   | P       |
|                   | • electrical configuration of the module;  |  | P       |
|                   | • physical layout of the modules in the BESS;  |  | P       |
|                   | • battery management system (BMS); and   |  | P       |
|                   | • other major components of the BESS;  |  | P       |
|                   | • the BESS enclosure overall dimensions and generic material;                                  |  | P       |
|                   | • battery system(s) may be tested as representative of the BESS;                               |  | P       |
|                   | • battery system complies with UL 1973 or not.   |  | N/A     |
| 5.3.3             | Any fire detection and suppression systems that are an integral part of the BESS.              | No fire detection and suppression system installed for the test. | N/A     |
| 5.3.4             | Further details included in the unit level and if applicable, installation level test reports. |  | P       |
| <b>5.4</b>        | <b>Flow Batteries</b>  |  |         |

| ANSI/CAN/UL 9540A |   |                 |         |
|-------------------|---|-----------------|---------|
| Clause            | Requirement – Test  | Result - Remark | Verdict |
| 5.4.1             | For flow batteries, to include the following info: <ul style="list-style-type: none"> <li>• the chemistry;</li> <li>• a generic description of the electrolyte (s);</li> <li>• the overall dimensions of the individual stack;</li> <li>• the electrical rating in capacity and nominal voltage of the cell stack.</li> </ul> And the Information of the complete flow battery system: <ul style="list-style-type: none"> <li>• the manufacturer's name and model number of the system;</li> <li>• the electrical rating in volts and rated storage capacity in Ah or Wh;</li> <li>• the number of cells and stacks in the system;</li> <li>• the maximum volume of electrolyte(s) for the system.</li> </ul> |                 | N/A     |
| 5.4.2             | The flow battery system complies with UL 1973 or not.   |                 | N/A     |
| 5.4.3             | Further details included in the flow battery thermal runaway determination level test report.   |                 | N/A     |
| <b>6</b>          | <b>Performance – General</b>  |                 |         |
| 6.1               | The tests in this standard are extreme abuse conditions conducted on electrochemical energy storage devices, which may result in various kind of hazards.   |                 | P       |
| 6.2               | At the conclusion of testing, samples discharged in accordance with the manufacturer' specifications.   |                 | P       |
|                   | All samples disposed of in accordance with local regulations.   |                 | P       |
| <b>9</b>          | <b>Unit Level</b>   |                 |         |
| <b>9.1</b>        | <b>Sample and test configuration</b>  |                 | --      |
| 9.1.1             | The unit level test shall be conducted with BESS units installed as described in the manufacturer's instructions and this section.  |                 | P       |
| 9.1.2             | The unit level test requires one initiating BESS unit and target adjacent BESS unit's representative of an installation.  |                 | P       |
|                   | (Modified by UL CRD-2020.10.21)<br>Tests conducted for indoor floor mounted installations for residential BESS may be considered representative of both indoor floors mounted and outdoor ground mounted installations.   |                 | P       |
|                   | Exception: Testing can be conducted outdoors for outdoor only installations with controlled environment.  |                 | N/A     |
| 9.1.3             | Depending upon the configuration and design of the BESS (e.g. the BESS is composed of multiple separate parts within separate enclosures), this testing to determine fire characterization can be done at the battery system level.   |                 | P       |
| 9.1.4             | The initiating BESS unit shall contain components representative of a BESS unit in a complete installation. Combustible components that interconnect the initiating and target BESS units shall be included.  |                 | P       |

| ANSI/CAN/UL 9540A |   |                                       |         |
|-------------------|---|---------------------------------------|---------|
| Clause            | Requirement – Test  | Result - Remark                       | Verdict |
| 9.1.5             | Target BESS units shall include the outer cabinet, racking, module enclosures, and components that retain cells components. The target BESS unit module enclosures do not need to contain cells.  | No cells in target BESS               | P       |
| 9.1.6             | The initiating BESS unit shall be at the maximum operating state of charge (MOSOC) for conducting the tests in this standard. After charging and prior to testing, the initiating BESS shall rest for a maximum period of 8h at room ambient. | See attachment 2: sample preparation. | P       |
| 9.1.7             | If a BESS unit includes an integral fire suppression system, there is an option of providing this with the DUT. If the BESS unit is provided with an optional integral fire suppression system, the system shall not be provided on the DUT.  |                                       | N/A     |
| 9.1.8             | Electronics and software controls such as the battery management system (BMS) in the BESS are not relied upon for this testing.   | BMS function disabled                 | P       |
|                   | This does not include a fire suppression control in accordance with UL 840 that is external to the BESS, but provided as part of an integral fire suppression system per 9.1.7.   |                                       | N/A     |
| <b>9.2</b>        | <b>Test method – Indoor floor mounted BESS units</b>  |                                       | --      |
| 9.2.1             | During the test, the test room environment shall be controlled to prevent drafts that may affect test results.  | See attachment 5                      | P       |
| 9.2.2             | Any access door(s) or panels on the initiating BESS unit and adjacent target BESS units shall be closed, latched and locked.  |                                       | P       |
| 9.2.3             | The initiating BESS unit shall be positioned adjacent to two instrumented wall sections.  | See attachment 3                      | P       |
| 9.2.4             | Instrumented wall sections shall extend not less than 0.49m horizontally beyond the exterior of the target BESS units.  |                                       | P       |
| 9.2.5             | Instrumented wall sections shall be at least 0.61m taller than the BESS unit height, but not less than 3.66m in height above the bottom surface of the unit.  |                                       | P       |
| 9.2.6             | The surface of the instrumented wall sections shall be covered with 16-mm (5/8-in) gypsum wall board and painted flat black.  |                                       | P       |
| 9.2.7             | The initiating BESS unit shall be centered underneath an appropriately sized smoke collection hood of an oxygen consumption calorimeter.  |                                       | P       |
| 9.2.8             | The light transmission in the calorimeter's exhaust duct shall be measured for the duration of the test, and the smoke release rate shall be calculated.  |                                       | P       |
| 9.2.9             | The chemical and convective heat release rates shall be measured for the duration of the test, respectively.  |                                       | P       |
| 9.2.10            | The heat release rate measurement system shall be calibrated using flows of 3.8, 7.6, 11.4 and 15.2 L/min (1, 2, 3 and 4 gpm) of heptane.   |                                       | P       |
| 9.2.11            | The convective heat release rate shall be measured using a thermopile, a velocity probe, and a Type K thermocouple, located in the exhaust system of the exhaust duct.  |                                       | P       |

| ANSI/CAN/UL 9540A |  |   |         |
|-------------------|--|---|---------|
| Clause            | Requirement – Test   | Result - Remark   | Verdict |
| 9.2.12            | The convective heat release rate shall be calculated using the following equation:<br>$HRR_c = V_e A \frac{353.22}{T_e} \int_{T_e}^T C_p dT$   | See attachment 9  | P       |
| 9.2.13            | The physical spacing between BESS units (both initiating and target) and adjacent walls shall be representative of the intended installation.  | See attachment 3  | P       |
| 9.2.14            | Separation distances shall be specified by the manufacturer for distance between:<br>a) The BESS units and the instrumented wall sections; and<br>b) Adjacent BESS units.  | See attachment 3<br>See attachment 3  | P<br>P  |
| 9.2.15            | Wall surface temperature measurements shall be collected for BESS intended for installation in locations with combustible construction.  | See attachment 6  | P       |
|                   | If the intended installation is composed completely of noncombustible construction in which wall assemblies, cables, wiring and any other combustible materials are not to be present in the BESS installation, then the report should note that the installation shall contain no combustible construction and that surface temperature rises can be deemed not applicable. |   | N/A     |
| 9.2.16            | Wall surface temperatures shall be measured in vertical array(s) at 152-mm (6-in) intervals for the full height of the instrumented wall sections.   | Using #30-gauge, Type-K exposed junction thermocouples;<br>See attachment 6           | P       |
|                   | The thermocouples for measuring the temperature on wall surfaces shall be horizontally positioned in the wall locations anticipated to receive the greatest thermal exposure from the initiating BESS unit.  |   | P       |
| 9.2.17            | Thermocouples shall be secured to gypsum surfaces by the use of staples placed over the insulated portion of the wires.  |   | P       |
|                   | The thermocouple tip shall be depressed into the gypsum so as to be flush with the gypsum surface at the point of measurement and held in thermal contact with the surface at that point by the use of pressure-sensitive paper tape.  |   | P       |
| 9.2.18            | Heat flux shall be measured with the sensing element of at least two water-cooled Schmidt-Boelter gauges at the surface of each instrumented wall:<br>a) Both are collinear with the vertical thermocouple array;  | Cheesecloth used, refer to 9.2.18.1, heat flux measurement on walls was not measured. | N/A     |
|                   | b) One is positioned at the elevation estimated to receive the greatest heat flux due to the thermal runaway of the initiating module; and   |   | N/A     |
|                   | c) One is positioned at the elevation estimated to receive the greatest heat flux during potential propagation of thermal runaway within the initiating BESS unit.   |   | N/A     |
| 9.2.18.1          | Heat flux measurements on walls may be waived for residential units that are tested with the cheesecloth indicator of 9.2.22.  | Cheesecloth indicator used.   | P       |

| ANSI/CAN/UL 9540A |  |  |         |
|-------------------|--|--|---------|
| Clause            | Requirement – Test   | Result - Remark  | Verdict |
| 9.2.18.2          | (added by UL CRD-2021.03.26)<br>With reference to 9.2.18, if b) and c) are deemed to be at the same location, only one gauge may be installed on the wall for the measurement.   |  | N/A     |
| 9.2.19            | Heat flux shall be measured with the sensing element of at least two water-cooled Schmidt-Boelter gauges at the surface of each adjacent target BESS unit that faces the initiating BESS unit:   |  | N/A     |
|                   | a) One is positioned at the elevation estimated to receive the greatest heat flux due to the thermal runaway of the initiating module within the initiating BESS; and  |  | N/A     |
|                   | b) One is positioned at the elevation estimated to receive the greatest surface heat flux due to the thermal runaway of the initiating BESS.   |  | N/A     |
| 9.2.19.1          | (added by UL CRD-2021.03.26)<br>Heat flux measurements on target units may be waived for residential units that are tested with the cheesecloth indicator of 9.2.22.   |  | P       |
| 9.2.19.2          | (added by UL CRD-2021.03.26)<br>With reference to 9.2.19, if a) and b) are deemed to be at the same location, only one gauge may be installed on the target unit for the measurement.  |  | N/A     |
| 9.2.20            | (added by UL CRD-2021.03.26)<br>For non-residential use BESS and outdoor ground mounted residential use BESS, heat flux shall be measured with the sensing element of at least one water-cooled Schmidt-Boelter or Gardon gauge positioned at the mid height of the initiating unit or the point where the majority of off-gas venting is expected from the initiating unit in the center of the accessible means of egress. |  | P       |
| 9.2.21            | Measure the temperature of:  |  | P       |
|                   | the surface proximate to the cells and between the cells and exposed face of the initiating module;  |  | P       |
|                   | Each non-initiating module enclosure within the initiating BESS unit;  |  | P       |
|                   | Convoluted enclosure interior geometries.  |  | P       |
| 9.2.22            | For residential use BESS, the DUT shall be covered with a single layer of cheese cloth ignition indicator.   |  | P       |
| 9.2.23            | An internal fire condition in accordance with the module level test shall be created within a single module in the initiating BESS unit:   |  | P       |
|                   | a) The position of the module shall be selected to present the greatest thermal exposure to adjacent modules, based on the results from the module level test; and   |  | P       |
|                   | b) The setup (i.e. type, quantity and positioning) of equipment for initiating thermal runaway in the module shall be the same as that used to initiate and propagate thermal runaway within the module level test (Section 8).  |  | P       |
| 9.2.24            | The composition, velocity and temperature of the initiating BESS unit vent gases shall be measured within the calorimeter's exhaust duct.  | Via the testing system which has the sensors in the exhaust duct | P       |

| ANSI/CAN/UL 9540A |  |   |         |
|-------------------|--|---|---------|
| Clause            | Requirement – Test   | Result - Remark                           | Verdict |
|                   | Gas composition shall be measured using a Fourier-Transform Infrared Spectrometer with a minimum resolution of 1 cm <sup>-1</sup> and a path length of at least 2.0 m (6.6 ft), or equivalent gas analyzer.  |   | P       |
|                   | Composition, velocity and temperature instrumentation shall be collocated with heat release rate calorimetry instrumentation.  |   | P       |
| 9.2.25            | The hydrocarbon components of the vent gas composition shall be measured using flame ionization detection.   | Integrated FID in the testing system used | P       |
| 9.2.26            | The test shall be terminated if:   |   | P       |
|                   | a) Temperatures measured inside each module within the initiating BESS unit return to ambient temperature;   |   | P       |
|                   | b) The fire propagates to adjacent units or to adjacent walls; or  |   | N/A     |
|                   | c) A condition hazardous to test staff or the test facility requires mitigation.   |   | N/A     |
| 9.2.27            | For residential use systems, the gas collection data shall be compared to the smallest room installation specified by the manufacturer to determine if the flammable gas collected exceeds 25% LFL in air.   |   | N/A     |
| <b>9.3</b>        | <b>Test method – Outdoor ground mounted units</b>  |   | --      |
| 9.3.1             | Outdoor ground mounted non-residential use BESS being evaluated for installation in close proximity to buildings and structures.   |   | P       |
|                   | If intended for outdoor use only installations, the smoke release rate, the convective and chemical heat release rate and content, velocity and temperature of the released vent gases need not be measured. |   | N/A     |
| 9.3.2             | Outdoor ground mounted residential use BESS being evaluated for installation in close proximity to buildings and structures.   |   | P       |
|                   | Heat flux measurements for the accessible means of egress.   |   | P       |
|                   | If intended for outdoor use only installations, the smoke release rate, the convective and chemical heat release rate and content, velocity and temperature of the released vent gases need not be measured. |   | N/A     |
| 9.3.3             | Test samples shall be installed as shown in Figure 9.2 in proximity to an instrumented wall section.   |   | P       |
|                   | The sample shall be mounted on a support substrate and spaced from the wall in accordance with the minimum separation distances specified by the manufacturer.   |   | P       |
|                   | Exception: If the manufacturer requires installation against non-flammable material, the test setup may include manufacturer recommended backing material between the unit and plywood wall.                 |   | N/A     |

| ANSI/CAN/UL 9540A |   |                 |         |
|-------------------|---|-----------------|---------|
| Clause            | Requirement – Test  | Result - Remark | Verdict |
| 9.3.4             | Target BESS shall be installed on each side of the initiating BESS and keep the min. separation distances specified by the manufacturer.  |                 | P       |
| <b>9.4</b>        | <b>Test Method – Indoor wall mounted units</b>  |                 | --      |
| 9.4.1             | Testing of indoor wall mounted BESS shall be in accordance with Section 9.2, except as modified in this section.  |                 | N/A     |
| 9.4.2             | Conduct testing in a standard NFPA 286 fire test room (12 x 8 x 8-ft) high, with a 2-1/2 x 7-ft high opening.   |                 | N/A     |
| 9.4.2.1           | (Added by UL CRD-2020.10.21)<br>BESS intended for residential installations only may be tested using instrumented wall sections not less than 2.44m (8-ft) in height & width instead of the test room.                              |                 | N/A     |
| 9.4.3             | The initiating BESS unit shall be positioned on the wall opposite of the door opening, with the center located 4-ft above the floor, and halfway between adjacent walls.  |                 | N/A     |
| 9.4.3.1           | (added by UL CRD-2020.10.21)<br>When residential BESS are tested in accordance with 9.4.2.1, the initiating BESS unit shall be positioned with the center located 1.22m (4-ft) above the floor, and halfway between adjacent walls. |                 | N/A     |
| 9.4.4             | Target BESS shall be installed on the wall on each side of the initiating BESS, at the same height above the floor as the initiating BESS.  |                 | N/A     |
| 9.4.5             | The wall on which the initiating and target BESS units are mounted shall be instrumented.   |                 | N/A     |
| 9.4.6             | For residential use systems, the gas collection data gathered in 9.2 shall be compared to the smallest room installation specified by the manufacturer to determine if the flammable gas collected exceeds 25% LFL in air.          |                 | N/A     |
| 9.4.7             | For residential use BESS, the DUT shall be covered with a single layer of cheese cloth ignition indicator.  |                 | N/A     |
| 9.4.8             | (added by UL CRD-2020.10.21)<br>When testing BESS for residential only installations, the criteria in 9.2.9, 9.2.18 and 9.2.19 may be waived.   |                 | N/A     |
| <b>9.5</b>        | <b>Test Method – Outdoor wall mounted units</b>   |                 | --      |
| 9.5.1             | Testing of outdoor wall mounted BESS shall be in accordance with Section 9.2, except as modified in this section.   |                 | N/A     |
|                   | If intended for outdoor use only wall mount installations, the smoke release rate, the convective and chemical heat release rate; and the content, velocity and temperature of the released vent gases need not be measured.        |                 | N/A     |
| 9.5.2             | Test samples shall be mounted on an instrumented wall (undersurface of the eave shown in Figure 9.4).   |                 | N/A     |
| 9.5.3             | The initiating BESS unit shall be positioned on the instrumented wall, with its center located 4-ft above the floor, and halfway between wall edges.  |                 | N/A     |
| 9.5.4             | Target BESS shall be installed on the wall on each side of the initiating BESS, at the same height above the floor as the initiating BESS and keep the min. separation distances specified by the manufacturer.                     |                 | N/A     |

| ANSI/CAN/UL 9540A |  |  |         |
|-------------------|--|--|---------|
| Clause            | Requirement – Test   | Result - Remark  | Verdict |
| 9.5.5             | The wall on which the initiating and target BESS units are mounted shall be instrumented.  |  | N/A     |
| 9.5.6             | For residential use BESS, the DUT shall be covered with a single layer of cheese cloth ignition indicator.   |  | N/A     |
| <b>9.6</b>        | <b>Rooftop and open garage installations</b>   |  | P       |
| 9.6.1             | Testing of BESS intended for non-residential use rooftop or open garage installations shall be in accordance with 9.2.   |  | P       |
| 9.6.2             | If intended for rooftop and open garage use only installations, the smoke release rate, the convective and chemical heat release rate and content, velocity and temperature of the released vent gases need not be measured. |  | P       |
| <b>9.7</b>        | <b>Unit level test report</b>  |  | --      |
| 9.7.1             | The report on the unit level testing shall identify the type of installation being tested, as follows:   |  | P       |
|                   | a) Indoor floor mounted non-residential use BESS;  |  | P       |
|                   | b) Indoor floor mounted residential use BESS;  |  | N/A     |
|                   | c) Outdoor ground mounted non-residential use BESS;  |  | P       |
|                   | d) Outdoor ground mounted residential use BESS;  |  | N/A     |
|                   | e) Indoor wall mounted non-residential use BESS;   |  | N/A     |
|                   | f) Indoor wall mounted residential use BESS;   |  | N/A     |
|                   | g) Outdoor wall mounted non-residential use BESS;  |  | N/A     |
|                   | h) Outdoor wall mounted residential use BESS;  |  | N/A     |
|                   | i) Rooftop installed non-residential use BESS; or  |  | P       |
|                   | j) Open garage installed non-residential use BESS.   |  | P       |
| 9.7.2             | If testing is intended to represent more than one installation type, this shall be noted in the report.  |  | P       |
| 9.7.3             | The report shall include the following, as applicable:   |  | P       |
|                   | a) Unit manufacturer name and model number (and whether UL 9540 compliant);  | See unit information   | P       |
|                   | b) Number of modules in the initiating BESS unit;  | See Attachment 3   | P       |
|                   | c) The construction of the initiating BESS unit per 5.3;   | See unit information   | P       |
|                   | d) Fire protection features/detection/suppression systems within unit;   | No fire detection and suppression system installed for the test. | N/A     |
|                   | e) Module voltage(s) corresponding to the tested SOC;  | See Attachment 2   | P       |
|                   | f) The thermal runaway initiation method used;   | See Attachment 4   | P       |
|                   | g) Location of the initiating module within the BESS unit;   | See Attachment 3   | P       |
|                   | h) Diagram and dimensions of the test setup including mounting location of the initiating and target BESS units, and the locations of walls, ceilings, and soffits;  | See Attachment 3   | P       |
|                   | i) Observation of any flaming outside the initiating BESS enclosure and the maximum flame extension;   | See Attachment 5   | P       |

| ANSI/CAN/UL 9540A          |  |   |         |
|----------------------------|--|---|---------|
| Clause                     | Requirement – Test   | Result - Remark   | Verdict |
|                            | j) Chemical and convective heat release rate versus time data;   | See Attachment 8 and attachment 9   | P       |
|                            | k) Separation distances from the initiating BESS unit to target walls (A and C in Figure 9.1);   | See Attachment 3  | P       |
|                            | l) Separation distances from the initiating BESS unit to target BESS units (D and H in Figure 9.1);  | See Attachment 3  | P       |
|                            | m) The maximum wall surface and target BESS temperatures achieved during the test and the location of the measuring thermocouple;  | See Attachment 6  | P       |
|                            | n) The maximum ceiling or soffit surface temperatures achieved during the indoor or outdoor wall mounted test and the location of the measuring thermocouple;  | See Attachment 6  | P       |
|                            | o) The maximum incident heat flux on target wall surfaces and target BESS units;   | Cheesecloth used, refer to 9.2.18.1, heat flux measurement on walls was not measured. | N/A     |
|                            | p) The maximum incident heat flux on target ceiling or soffit surfaces achieved during the indoor or outdoor wall mounted test;  | Cheesecloth used, refer to 9.2.18.1, heat flux measurement on walls was not measured. | N/A     |
|                            | q) Gas generation and composition data   | See Attachment 10   | P       |
|                            | r) Peak smoke release rate and total smoke release data;   | See Attachment 11   | P       |
|                            | s) Indication of the activation of integral fire protection systems and if activated the time into the test at which activation occurred;  | No fire detection and suppression system installed for the test.                      | N/A     |
|                            | t) Observation of flying debris or explosive discharge of gases;   | No observation.   | P       |
|                            | u) Observation of re-ignition(s) from thermal runaway events;  | No observation.   | P       |
|                            | v) Observation(s) of sparks, electrical arcs, or other electrical events;  | See Attachment 5  | P       |
|                            | w) Observations of the damage to:  | See Attachment 1  | P       |
|                            | 1) The initiating BESS unit;   | See Attachment 1  | P       |
|                            | 2) Target BESS units;  | See Attachment 1  | P       |
|                            | 3) Adjacent walls, ceilings, or soffits; and   | See Attachment 1  | P       |
|                            | x) Photos and video of the test.   | See Attachment 1 and 20250315-1.mp4 to 20250315-9.mp4                                 | P       |
| <b>9.8</b>                 | <b>Performance at unit level testing</b>   |   | --      |
| 9.8.1                      | Installation level testing in Section 10 is not required if the performance conditions outlined in Table 9.1 are met during the unit level test.   |   | P       |
|                            | <b>Non-Residential Installations</b>   |   | --      |
| Indoor<br>Floor<br>Mounted | a) Flaming outside the initiating BESS unit is not observed;   | Not observed.   | P       |
|                            | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |   | P       |
|                            | c) For BESS units intended for installation in locations with combustible constructions, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;    |   | P       |

| ANSI/CAN/UL 9540A            |  |                 |         |
|------------------------------|--|-----------------|---------|
| Clause                       | Requirement – Test   | Result - Remark | Verdict |
|                              | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            | Not observed.   | P       |
|                              | e) Heat flux in the center of the accessible means of egress shall not exceed 1.3 kW/m <sup>2</sup> .  |                 | P       |
| Outdoor<br>Ground<br>Mounted | a) If flaming outside of the unit is observed, separation distances to exposures shall be determined by greatest flame extension observed during test.   | Not observed    | P       |
|                              | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | P       |
|                              | c) For BESS units intended for installation near exposures, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;                                 |                 | P       |
|                              | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            | Not observed.   | P       |
|                              | e) Heat flux in the center of the accessible means of egress shall not exceed 1.3 kW/m <sup>2</sup> .  |                 | P       |
| Indoor<br>Wall<br>Mounted    | a) Flaming outside the initiating BESS unit is not observed;   |                 | N/A     |
|                              | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | N/A     |
|                              | c) For BESS units intended for installation in locations with combustible construction, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;     |                 | N/A     |
|                              | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            |                 | N/A     |
|                              | e) Heat flux in the center of the accessible means of egress shall not exceed 1.3 kW/m <sup>2</sup> .  |                 | N/A     |
| Outdoor<br>Wall<br>Mounted   | a) Flaming outside the initiating BESS unit is not observed;   |                 | N/A     |
|                              | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | N/A     |
|                              | c) For BESS units intended for installation on walls with combustible construction, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;         |                 | N/A     |

| ANSI/CAN/UL 9540A        |  |                 |         |
|--------------------------|--|-----------------|---------|
| Clause                   | Requirement – Test   | Result - Remark | Verdict |
|                          | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            |                 | N/A     |
|                          | e) Heat flux in the center of the accessible means of egress shall not exceed 1.3 kW/m <sup>2</sup> .  |                 | N/A     |
| Rooftop and Open Garages | a) If flaming outside the unit is observed, separation distances to exposures shall be determined by greatest flame extension observed during test;  |                 | P       |
|                          | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | P       |
|                          | c) For BESS units intended for installation in locations with combustible construction, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;     |                 | P       |
|                          | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            |                 | P       |
|                          | e) Heat flux in the center of the accessible means of egress shall not exceed 1.3 kW/m <sup>2</sup> .  |                 | P       |
|                          | <b>Residential Installations</b>   |                 | --      |
| Indoor Floor Mounted     | a) Flaming outside the initiating BESS unit is not observed as demonstrated by no flaming or charring of the cheesecloth indicator;  |                 | N/A     |
|                          | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | N/A     |
|                          | c) For BESS units intended for installation in locations with combustible construction, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;     |                 | N/A     |
|                          | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            |                 | N/A     |
|                          | e) The concentration of flammable gas does not exceed 25% LFL in air for the smallest specified room installation size.  |                 | N/A     |
| Outdoor Ground Mounted   | a) If flaming outside of the unit is observed, separation distances to exposures shall be determined by greatest flame extension observed during test.   |                 | N/A     |
|                          | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | N/A     |

| ANSI/CAN/UL 9540A    |  |                 |         |
|----------------------|--|-----------------|---------|
| Clause               | Requirement – Test   | Result - Remark | Verdict |
| Indoor Wall Mounted  | c) For BESS units intended for installation near exposures, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;                                 |                 | N/A     |
|                      | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            |                 | N/A     |
|                      | e) Heat flux in the center of the accessible means of egress shall not exceed 1.3 kW/m <sup>2</sup> .  |                 | N/A     |
|                      | a) Flaming outside the initiating BESS unit is not observed as demonstrated by no flaming or charring of the cheesecloth indicator;  |                 | N/A     |
|                      | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | N/A     |
| Outdoor Wall Mounted | c) For BESS units intended for installation in locations with combustible construction, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15;     |                 | N/A     |
|                      | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases; and            |                 | N/A     |
|                      | e) The concentration of flammable gas does not exceed 25% LFL for the smallest intended room installation size.  |                 | N/A     |
|                      | a) Flaming outside the initiating BESS unit is not observed as demonstrated by no flaming or charring of the cheesecloth indicator;  |                 | N/A     |
|                      | b) Surface temperatures of modules within the target BESS units adjacent to the initiating BESS unit do not exceed the temperature at which thermally initiated cell venting occurs, as determined in 7.3.1.8; |                 | N/A     |
|                      | c) For BESS units intended for installation in locations with combustible construction, surface temperature measurements on wall surfaces do not exceed 97°C of temperature rise above ambient per 9.2.15; and |                 | N/A     |
|                      | d) Explosion hazards are not observed, including deflagration, detonation or accumulation (to within the flammability limits in an amount that can cause a deflagration) of battery vent gases.                |                 | N/A     |

**Attachment 1 Photos**

The battery system before test




Front side

During test



Smoke release from initiating unit

The battery system after test



Internal view of initiating module, after test







**Attachment 2 Sample preparation**


The test energy storage system consists of 25 modules.

The unit was conditioned, prior to testing, through charge and discharge cycles for 2 cycles per the manufacturer's instructions to verify that the unit was functional.

As manufacturer specified, the module was charged with 6.0288kW power to module end charge voltage 42.6V, then keep the module stabilized for 10 minutes. After being stabilized, the module was discharged, the module was discharged with 6.0288kW power to module end discharge voltage 34.8V, then keep the module stabilized for 10 minutes.

After repeating the cycle above twice and then unit was fully charged with 6.0288kW power to unit end charge voltage 42.6V, and before testing, the unit was stabilized for about 4 hours. During conditioning the ambient temperature maintained in  $25 \pm 5^\circ\text{C}$  and  $50 \pm 25\%$  RH.

Cycling curve of the initiating unit is shown below.




**Attachment 3 Arrangement of the unit**

The installation information was provided by the client as below.


|                             |   |  |
|-----------------------------|---|--|
| Intended use location ..... | <input type="checkbox"/> Residential                                | <input checked="" type="checkbox"/> Non-residential        |
|                             | <input checked="" type="checkbox"/> Non-residential rooftop         |  |
|                             | <input checked="" type="checkbox"/> Non-residential open garage use |  |
| Type of installation .....  | <input checked="" type="checkbox"/> Indoor floor mounted            | <input checked="" type="checkbox"/> Outdoor ground mounted |
|                             | <input type="checkbox"/> Indoor wall mounted                        | <input type="checkbox"/> Outdoor wall mounted              |
| Row(s) of installation      | <input type="checkbox"/> Single                                     | <input checked="" type="checkbox"/> Multiple               |

Walls were constructed of 16 mm (5/8-inch) gypsum painted flat black.

Two unit were used for the purpose of the test. To identify the modules in each unit, the modules in each unit were numbered as the figure below.



Minimum separation distance from the units to instrumental walls were shown in below figure. Top view of the unit arrangement and separation distance from units to instrumental walls are shown in below figure. Due to the weight and size of the unit, the accuracy of the distance may have a 0.5 cm tolerance.



A= Distance from the initiating unit to target unit: min.30cm

B= Distance from the unit to instrumented wall A and B: min.10cm


C= Distance from the unit to egress or exposures: min.91.4cm

#### Attachment 4 Thermal runaway preparation

Initiating module 2 in initiating unit 1 was selected as the initiating module.

The initiating module was charged to 100% SOC and allowed to stabilize for a minimum of 1 h and a maximum of 8 h before the start of the test.

External heating method was used to initiate thermal runaway in the module. 2 flexible film heaters, rated 220VAC/880W each, sized 220mm x 180mm, were pasted on two big sides of cell 7.



Cell 7 was heated as the target cell at a rate of 4°C-7°C per minute until thermal runaway was occurred when thermal runaway occurred, the heater will de-energized immediately.

**Attachment 5 Observations and records**


Before the test, the initiating module 2 was charged to 100% SOC and stabilized for about 4 h before the start of the test.

Below table summarizes the details:

|  |  |       |                                 |       |
|--|--|-------|---------------------------------|-------|
| Ambient conditions at the initiation of the test:    | 20.1°C, 70.2%RH  |       |                                 |       |
| Electronics and software controls within the module? | <input checked="" type="checkbox"/> Yes, but not relied upon for this testing<br><input type="checkbox"/> No such controls   |       |                                 |       |
| Time when test was initiated:                        | 15 March 2024, 14:00   |       |                                 |       |
| Observations during test:                            | 1 <sup>st</sup> vented   | 14:52 | 1 <sup>st</sup> thermal runaway | 14:53 |
|  | 2 <sup>nd</sup> vented   | 14:53 | 2 <sup>nd</sup> thermal runaway | 14:54 |
|  | 3 <sup>rd</sup> vented   | 14:54 | 3 <sup>rd</sup> thermal runaway | 14:55 |
|  | 4 <sup>th</sup> vented   | 15:30 | 4 <sup>th</sup> thermal runaway | 15:31 |
|  | No flying debris or explosive discharge of gases.<br>No sparks, electrical arcs, or other electrical events.<br>No external flaming was observed   |       |                                 |       |
| Post-test evaluation:                                | In initiating unit 1, no thermal runaway propagation from initiating module 2 to other modules in initiating unit.<br><br>In initiating module 2, cell 7 went to thermal runaway, due to external heating. Cell 5, cell 6 and cell 8 in the initiating module 2 vented and went to thermal runaway due to thermal runaway propagation. Cell 2, cell 3, cell 4, cell 9, cell 10, cell 11 and cell 12 in the initiating module 2 vented.<br><br>No damage on target walls.<br>No damage on target units. |       |                                 |       |

**Attachment 6 Temperature measurements**


To monitor the cells temperature inside the initiating module 2, 13 thermocouples, Type K, were used. See below figure and table for detail location of the flexible heaters and thermocouples.



Heaters and thermocouple location inside the module

| Thermocouple No. | Thermocouple location on initiating module 2      |
|------------------|---|
| T1               | Centre of big side of cell 1 facing cell 2        |
| T2               | Centre of big side of cell 2 facing cell 3        |
| T3               | Centre of big side of cell 3 facing cell 4        |
| T4               | Centre of big side of cell 4 facing enclosure     |
| T5               | Centre of big side of cell 6 facing heater 1      |
| T6               | Centre of big side of cell 5 facing cell 6        |
| T7               | Between center of big side of cell 7 and heater 1 |
| T8               | Between center of big side of cell 7 and heater 2 |
| T9               | Centre of big side of cell 8 facing heater 2      |
| T10              | Centre of big side of cell 9 facing cell 10       |
| T11              | Centre of big side of cell 10 facing cell 11      |
| T12              | Centre of big side of cell 11 facing cell 12      |
| T13              | Centre of big side of cell 12 facing enclosure    |


Temperature describing cell to cell propagation in initiating module 2 voltage are show in below figure.



The maximum measured temperature of each location is shown in below table.


| Thermocouple No.                | Thermocouple location on initiating module 3      | Maximum temperature (°C) |
|---------------------------------|---|--------------------------|
| T1                              | Centre of big side of cell 1 facing cell 2        | 136.6                    |
| T2                              | Centre of big side of cell 2 facing cell 3        | 143.4                    |
| T3                              | Centre of big side of cell 3 facing cell 4        | 145.3                    |
| T4                              | Centre of big side of cell 4 facing enclosure     | 123.0                    |
| T5                              | Centre of big side of cell 6 facing heater 1      | 657.9                    |
| T6                              | Centre of big side of cell 5 facing cell 6        | 489.7                    |
| T7                              | Between center of big side of cell 7 and heater 1 | 645.0                    |
| T8                              | Between center of big side of cell 7 and heater 2 | 688.0                    |
| T9                              | Centre of big side of cell 8 facing heater 2      | 847.4                    |
| T10                             | Centre of big side of cell 9 facing cell 10       | 138.7                    |
| T11                             | Centre of big side of cell 10 facing cell 11      | 144.2                    |
| T12                             | Centre of big side of cell 11 facing cell 12      | 144.4                    |
| T13                             | Centre of big side of cell 12 facing enclosure    | 129.0                    |
| Max. system voltage, after test |   |                          |
| Voltage                         |   | 19.2V                    |

To monitor the surface temperature of initiating module 1, initiating module 2 and initiating module 3 in initiating unit 1, 3 thermocouples (number T14 to T16) were used, and detail location was shown in below figure and table.



Thermocouple's location in initiating module (Front View)

The measured surface temperature of initiating module 1, initiating module 2 and initiating module 3 in initiating unit 1 during test is shown in below figure.



The maximum measured temperature of each location is shown in below table.

| Thermocouple No. | Location  | Maximum measured temperature (°C) |
|------------------|---|-----------------------------------|
| T14              | Metal enclosure, top of the initiating module 1 | 103.6                             |
| T15              | Metal enclosure, top of the initiating module 2 | 175.1                             |
| T16              | Metal enclosure, top of the initiating module 3 | 41.6                              |


To monitor the surface temperature of instrumental walls, vertical array at 152 mm intervals for the full height of the instrumented wall sections using Type K, 30 AWG thermocouples were used.

The thermocouple array A was on instrumental wall A, collinear with vertical central line of initiating unit 1 back surface.

The thermocouple array B was on the left enclosure surface of target unit 1, collinear with vertical central line of initiating unit 1 right surface.


The thermocouple array C was on the right enclosure surface of target unit 2, collinear with vertical central line of initiating unit 1 left surface.

The detailed locations of the thermocouple arrays are shown in the below figure.




The first thermocouple starts from 152 mm from the ground. A total of 41 thermocouples were used for array A, array B and array C. The thermocouples were numbered from low to high as TA1 to TA15 for thermocouple array A, TA16 to TA29 for thermocouple array B, TA30 to TA41 for thermocouple array C.


The measured surface temperature of instrumental wall A during test is shown in below figure.



The measured surface temperature of the left enclosure surface of target unit 1 during test is shown in below figure.



The measured surface temperature of the right enclosure surface of target unit 2 during test is shown in below figure.




The maximum measured surface temperature of each location on the instrumental wall A, the left enclosure surface of target unit 1 and the right enclosure surface of target unit 2 is shown in the below table.

| Thermocouple No.  | Maximum temperature (°C) |
|---|--------------------------|
| Surface temperature on instrumental wall A                          |                          |
| TA1   | 26.8                     |
| TA2   | 25.8                     |
| TA3   | 28.9                     |
| TA4   | 37.0                     |
| TA5   | 39.5                     |
| TA6   | 32.0                     |
| TA7   | 29.9                     |
| TA8   | 29.0                     |
| TA9   | 29.6                     |
| TA10  | 27.8                     |
| TA11  | 27.2                     |
| TA12  | 26.6                     |
| TA13  | 27.4                     |
| TA14  | 25.1                     |
| TA15  | 24.5                     |
| Surface temperature on left enclosure surface of target unit 1      |                          |
| TA16  | 22.2                     |
| TA17  | 22.9                     |
| TA18  | 21.9                     |
| TA19  | 22.1                     |
| TA20  | 22.3                     |
| TA21  | 23.2                     |
| TA22  | 22.1                     |
| TA23  | 22.1                     |
| TA24  | 22.6                     |
| TA25  | 22.0                     |
| TA26  | 22.3                     |
| TA27  | 22.1                     |
| TA28  | 21.9                     |
| TA29  | 22.5                     |
| Surface temperature on the right enclosure surface of target unit 2 |                          |
| TA30  | 25.0                     |
| TA31  | 24.5                     |
| TA32  | 25.3                     |
| TA33  | 24.8                     |
| TA34  | 26.8                     |
| TA35  | 25.3                     |
| TA36  | 27.3                     |
| TA37  | 27.1                     |
| TA38  | 25.4                     |
| TA39  | 25.1                     |
| TA40  | 23.7                     |
| TA41  | 22.6                     |

**Attachment 7 Heat flux measurements**


Measure Heat flux in the center of the accessible means of egress: 0.029KW/m<sup>2</sup>



**Attachment 8 Chemical heat release rate measurement**

The chemical heat release rate was measured by a measurement system consisting of a paramagnetic oxygen analyzer, non-dispersive infrared carbon dioxide and carbon monoxide analyzer, velocity probe, and a Type K thermocouple. The instrumentation was located in the exhaust duct of the heat release rate calorimeter at a location that minimizes the influence of bends or exhaust devices.

Measured peak chemical heat release rate HRRt: 9.88kW.



Chemical heat release rate (HRRt) versus time data curve

### Attachment 9 Convective heat release rate measurement

The convective heat release rate was measured using thermopile, a velocity probe, and a Type K thermocouple, located in the exhaust system of the exhaust duct.

The convective heat release rate was calculated at each of the flows as follows:

$$HRR_c = V_e A \frac{353.22}{T_e} \int_{T_o}^T C_p dT$$

Where:

$HRR_c$  = The convective heat release rate (kW)

$V_e$  = The exhaust velocity (m/s)

$A$  = The exhaust duct cross sectional area ( $m^2$ )

$T_e$  = The temperature at the location where exhaust velocity is measured (K)

$353.22/T_e$  = The density of air at the velocity measurement location ( $kg/m^3$ )

$T_o$  = The ambient temperature (K) in the test room

$T$  = The thermopile temperature (K)

$$\int_{T_o}^T C_p dT = A_0(T - T_o) + A_1 / 2(T^2 - T_o^2) + A_2 / 3(T^3 - T_o^3) + A_3 / 4(T^4 - T_o^4)$$

$C_p$  = Specific heat of air (kJ/kg-K), given as  $C_p = A_0 + A_1 T + A_2 T^2 + A_3 T^3$ , where:


$A_0 = 0.9950$

$A_1 = -5.29933E-05$

$A_2 = 3.21022E-07$

$A_3 = -1.22004E-10$

The measured peak convective heat release rate  $HRR_c$  was 0 kW.



Convective heat release rate ( $HRR_c$ ) versus time data curve

#### Attachment 10 Gas generation measurement

Vent gas composition were measured using a Fourier-Transform Infrared Spectrometer with a resolution of  $0.5 \text{ cm}^{-1}$  and a path length of 5.11 m within the calorimeter's exhaust duct. And the composition, velocity and temperature of the vent gases were measured within the calorimeter's exhaust duct.

The hydrocarbon content of the vent gas was measured using flame ionization detection.


The Hydrogen content was measured with a palladium-nickel thin-film solid state sensor, a heat conduction sensor and an electrochemistry sensor.



The Hydrogen was not detected by the palladium-nickel thin-film solid state sensor and heat conduction sensor. The Hydrogen content value in the below table was measured by electrochemistry sensor.



The gas composition and volume are shown in the below table.

| Gas type   | Gas components        |                                 | Total volume of gas (L) |
|--|-----------------------|---------------------------------|-------------------------|
| Hydrocarbon species  | Methane               | CH <sub>4</sub>                 | 102.08                  |
|  | Acetylene             | C <sub>2</sub> H <sub>2</sub>   | 1.68                    |
|  | Ethylene              | C <sub>2</sub> H <sub>4</sub>   | 49.95                   |
|  | Ethane                | C <sub>2</sub> H <sub>6</sub>   | 6.07                    |
|  | Propylene             | C <sub>3</sub> H <sub>6</sub>   | 41.32                   |
|  | Propane               | C <sub>3</sub> H <sub>8</sub>   | 5.14                    |
| Hydrogen halide species  | Hydrogen Fluoride     | HF                              | 6.27                    |
| Other species  | Carbon Monoxide       | CO                              | 98.39                   |
|  | Carbon Dioxide        | CO <sub>2</sub>                 | 244.07                  |
|  | Ethylmethyl carbonate | C <sub>4</sub> H <sub>8</sub> O | 34.15                   |
|  | Oil as octane         | --                              | 3.46                    |
|  | Hydrogen              | H <sub>2</sub>                  | 692.32                  |
| Total Hydrocarbons (equivalent to CH <sub>4</sub> , measured by FID) |                       |                                 | 177.38                  |


Concentration of different gas components according to gas species classification was displayed as following graphs.








Hydrogen halide species






Concentration of Hydrogen Fluoride (HF)

Other species




Concentration of Carbon Monoxide (CO)






Concentration of Oil as octane



Concentration of Hydrogen ( $H_2$ )  
Electrochemical sensor



**Attachment 11 Smoke release rate measurement**

Smoke release rate shall be calculated as follows:

$$SRR = 2.303 \left( \frac{V}{D} \right) \log_{10} \left( \frac{I_o}{I} \right)$$

Where:

SRR = Smoke release rate ( $\text{m}^2/\text{s}$ )

V = Volumetric exhaust duct flow rate ( $\text{m}^3/\text{s}$ )

D = duct diameter (m)

$I_o$  = Light transmission signal of clear (pre-test) beam (V)


I = Light transmission signal during test (V)

The smoke release rate measurement system was self-checked using calibrated light filter before test.


Measured peak smoke release rate SRR:  $0.1987 \text{ m}^2/\text{s}$

Measured total smoke release TSR:  $109.4 \text{ m}^2$

Smoke release rate (SRR) versus time data curve



Total smoke release (TSR) versus time data curve



**Attachment 12 Equipment list**

| No. | Equipment                                    | Model                                     | Rating   | Inventory no. | Initial cal. date |
|-----|--|---|--|---------------|-------------------|
| 1   | Ambient monitor                              | RS210                                     | 0%~ 100%RH, -20~70°C   | SA047-106     | 2024-09-11        |
| 2   | Digital multi-meter                          | 175C                                      | 0~1000Vdc, 0~1000Vac   | SA012-194     | 2024-07-24        |
| 3   | Charge /discharge equipment                  | BAT-NE-250-V001                           | Max 900V, 400A   | SA064-40      | 2024-07-23        |
| 4   | 3MW lithium battery heat release calorimeter | RHR                                       | 0-1100°C, 0~0.4Mpa   | SA200-69      | 2024-09-27        |
| 5   | Gas analyzer                                 | ABB AO2020                                | O <sub>2</sub> : 0-25%, CO <sub>2</sub> : 0-10%, CO: 0-1%                                | SA200-69-01   | 2024-08-27        |
| 6   | Gas mass flowmeter                           | HZ020-LK2-S-L-C13-R4-DI2-DB9M-050-500-101 | 0-500SLPM  | SA200-69-02   | 2024-04-28        |
| 7   | The total hydrocarbon gas analyzer           | ABB EL3020                                | TCH: 0-10000ppm, CH <sub>4</sub> : 0-10000ppm, C <sub>3</sub> H <sub>8</sub> : 0-3300ppm | SA200-70      | 2024-08-27        |
| 8   | Palladium-nickel hydrogen analyzer           | H2SCAN 710B                               | H <sub>2</sub> :0.1%-10%   | SA200-71      | 2024-08-23        |
| 9   | On-line Fourier infrared analyzer            | MKS 6030                                  | 500cm <sup>-1</sup> ~4200cm <sup>-1</sup> , 0.01ppm-100%                                 | SA200-76      | 2025-01-07        |
| 10  | Temperature and voltage acquisition device   | 79 channels                               | 0-1100°C, 0-500V   | SA200-73      | 2024-08-23        |
| 11  | Electrochemical hydrogen analyzer            | JKBS-J001-H2-Y05                          | 0-1000ppm  | SA200-74      | 2025-01-07        |
| 12  | Electronic weighing scale                    | E310W                                     | 10~3000kg  | SA028-59      | 2024-12-05        |

End of test report