

**Temperatuureffect van te melden systemen op bestaande systemen:**

	<b>S-4</b>	<b>S-5</b>	<b>S-6</b>	<b>S-7</b>	<b>S-8</b>	<b>S-9</b>	<b>S-10</b>	<b>S-11</b>	<b>S-12</b>	<b>S-13</b>
<b>Te melden S-1</b>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Te melden S-2</b>	0.0	0.0	-0.058	-0.106	-0.167	0.0	0.0	0.0	0.0	0.0
<b>Te melden S-3</b>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

**Temperatuureffecten per systeem (gemiddeld over alle boringen):**

<b>Type</b>	<b>systeem code</b>	<b>T-effect Totaal</b>	<b>T-effect te melding</b>	<b>T-effect bestaande</b>
Te melden	S-1	-0.197	-0.197	0.0
Te melden	S-2	-0.148	-0.108	-0.04
Te melden	S-3	-0.093	-0.093	0.0
Bestaand	S-4	-0.908	0.0	-0.908
Bestaand	S-5	-1.237	0.0	-1.237
Bestaand	S-6	-1.331	-0.058	-1.273
Bestaand	S-7	-1.32	-0.106	-1.214
Bestaand	S-8	-1.047	-0.167	-0.879
Bestaand	S-9	-0.92	0.0	-0.92
Bestaand	S-10	-1.187	0.0	-1.187
Bestaand	S-11	-1.302	0.0	-1.302
Bestaand	S-12	-1.138	0.0	-1.138
Bestaand	S-13	-0.905	0.0	-0.905