

| Stal              | Aantal kuikens | Ventilatie behoefte | Totale ventilatiebehoefte | Capaciteit warmtewisselaar | Kuikens op WW | Nog te verdelen | Dak kuikens | Gevel Kuikens |  |
|-------------------|----------------|---------------------|---------------------------|----------------------------|---------------|-----------------|-------------|---------------|--|
| 1                 | 27821          | 2.4                 | 66770.4                   | 28000                      | 11667         | 16154           | 8307        | 7847          |  |
| 2                 | 18832          | 2.4                 | 45196.8                   | 20000                      | 8333          | 10499           | 6052        | 4447          |  |
| 3                 | 19902          | 2.4                 | 47764.8                   | 20000                      | 8333          | 11569           | 7099        | 4470          |  |
| Nokventilatie     |                |                     |                           |                            |               |                 |             |               |  |
|                   | Diameter       | Aantal              | Capaciteit                | totale capaciteit          |               |                 |             |               |  |
| 1                 | 0.82           | 7                   | 18285                     | 127995                     |               |                 |             |               |  |
| 2                 | 0.82           | 6                   | 18285                     | 109710                     |               |                 |             |               |  |
| 3                 | 0.82           | 7                   | 18285                     | 127995                     |               |                 |             |               |  |
| Gevelventilatie   |                |                     |                           |                            |               |                 |             |               |  |
|                   | Diameter       | Aantal              | Capaciteit                | totale capaciteit          |               |                 |             |               |  |
| 1                 | 1.4            | 3                   | 40300                     | 120900                     |               |                 |             |               |  |
| 2                 | 1.4            | 2                   | 40300                     | 80600                      |               |                 |             |               |  |
| 3                 | 1.4            | 2                   | 40300                     | 80600                      |               |                 |             |               |  |
| Totale capaciteit |                |                     |                           |                            |               |                 |             |               |  |
|                   | Nokventilatie  | Gevelventilatie     | Totale capaciteit         | Verdeel Nok                |               | Verdeel gevel   |             |               |  |
| 1                 | 127995         | 120900              | 248895                    | 0.514252998                |               | 0.485747002     |             |               |  |
| 2                 | 109710         | 80600               | 190310                    | 0.576480479                | 0.423519521   |                 |             |               |  |
| 3                 | 127995         | 80600               | 208595                    | 0.613605312                | 0.386394688   |                 |             |               |  |

| Stal | Aantal kuikens | Kuikens op WW | Nog te verdelen | Dak kuikens | Gevel Kuikens |
|------|----------------|---------------|-----------------|-------------|---------------|
| 1    | 9.612258959    | 4.030991886   |                 | 2.870099391 | 2.711167681   |
| 2    | 6.506526031    | 2.879082488   |                 | 2.090988506 | 1.536455037   |
| 3    | 6.87621501     | 2.879082488   |                 | 2.452730899 | 1.544401623   |

| Stal | Emissiepunt     | NOx emissie |
|------|-----------------|-------------|
| 1    | Warmtewisselaar | 4.0310      |
|      | Nok             | 2.8701      |
|      | Gevel           | 2.7112      |
| 2    | Warmtewisselaar | 2.8791      |
|      | Nok             | 2.0910      |
|      | Gevel           | 1.5365      |
| 3    | Warmtewisselaar | 2.8791      |
|      | Nok             | 2.4527      |
|      | Gevel           | 1.5444      |

| Stal | Aantal opfokhennen | Ventilatie behoefte | Totale ventilatiebehoefte | Capaciteit warmtewisselaar | Opfokhennen op WW | Opfokhennen dak |
|------|--------------------|---------------------|---------------------------|----------------------------|-------------------|-----------------|
| G    | 30000              | 1.8                 | 54000                     | 12000                      | 6667              | 23333           |