

Tabel 1: Fundex(combi)palen of gelijkwaardig

 Goedgekeurd
 SOB , 15:04:40, 23-7-2025

Sondering [nr.]	Paalpunctniveau [t.o.v. NAP]	Rekenw. netto draagkracht Rc;d;netto [kN]	
		410/500 mm	460/560 mm
1	-22.00	470	610
	-22.50	610	740
	-23.00	610	740
	-23.50	610	530
	-24.00	440	530
	-26.50	930	1120
	-27.00	1010	1210
	-27.50	1100	1320
	-28.00	1150	1320
2	-22.00	320	380
	-22.50	320	390
	-23.00	350	430
	-25.00	750	930
	-25.50	800	980
	-26.00	850	1050
	-26.50	1200	1460
	-27.00	1330	1600
	-27.50	1430	1720
	-28.00	1640	2010
3	-22.00	660	810
	-22.50	900	1110
	-23.00	960	1110
	-23.50	960	1110
	-24.00	960	1030
	-24.50	790	970
	-25.00	810	980
	-25.50	810	980
	-26.00	790	950
	-26.50	1090	1350
	-27.00	1380	1720
	-27.50	1630	1970
	-28.00	1870	2250
4	-22.00	390	470
	-22.50	380	480
	-23.00	550	700

Sondering [nr.]	Paalpuntniveau [t.o.v. NAP]	Rekenw. netto draagkracht Rc;d;netto [kN]	
		410/500 mm	460/560 mm
4	-23.50	700	880
	-24.00	830	1030
	-24.50	1010	1240
	-25.00	1060	1310
	-25.50	1200	1450
	-26.00	1290	1560
	-26.50	1420	1670
	-27.00	1420	1670
	-27.50	1430	1720
	-28.00	1450	1750
5	-22.00	390	470
	-22.50	580	720
	-23.00	610	770
	-23.50	710	900
	-24.00	880	1090
	-24.50	970	1180
	-25.00	1040	1280
	-25.50	1190	1440
	-26.00	1250	1510
	-26.50	1260	1510
	-27.00	1310	1570
	-27.50	1400	1670
	-28.00	1560	1900
6	-22.00	930	1110
	-22.50	980	1140
	-23.00	980	1140
	-23.50	980	1200
	-24.00	1020	1240
	-24.50	1040	1270
	-25.00	1080	1330
	-25.50	1300	1570
	-26.00	1300	1570
	-26.50	1560	1890
	-27.00	1640	1980
	-27.50	1710	2050
	-28.00	1750	2120
7	-22.00	640	800
	-25.50	1010	1220
	-26.00	1110	1330
	-26.50	1130	1350
	-27.00	1320	1570

Sondering [nr.]	Paalpuntniveau [t.o.v. NAP]	Rekenw. netto draagkracht Rc;d;netto [kN]	
		410/500 mm	460/560 mm
7	-27.50	1450	1720
	-28.00	1630	1930
8	-22.00	600	690
	-22.50	600	690
	-23.00	580	720
	-25.50	1160	1410
	-26.00	1300	1570
	-26.50	1490	1790
	-27.00	1760	2110
	-27.50	1910	2280
	-28.00	2020	2390
9	-22.00	440	520
	-22.50	440	520
	-23.00	440	550
	-26.00	900	1000
	-26.50	900	1000
	-27.00	780	940
10	-22.00	470	570
	-22.50	490	610
	-23.00	500	620
	-23.50	720	880
	-24.00	770	950
	-24.50	840	1030
	-25.00	1030	1280
	-25.50	1360	1590
	-26.00	1390	1690
	-26.50	1470	1760
	-27.00	1550	1850
	-27.50	1620	1930
	-28.00	1740	2090
S201	-22.00	420	530
	-22.50	480	600
	-23.00	560	690
	-23.50	590	720
	-24.00	590	720
	-24.50	630	760
	-25.00	630	770
	-25.50	630	770
	-26.00	980	1210
	-26.50	1240	1510
	-27.00	1340	1620

Sondering [nr.]	Paalpuntniveau [t.o.v. NAP]	Rekenw. netto draagkracht Rc;d;netto [kN]	
		410/500 mm	460/560 mm
	-27.50	1400	1680
	-28.00	1510	1810
S202	-23.00	680	840
	-23.50	710	870
	-24.00	950	1160
	-24.50	990	1210
	-25.00	1200	1460
	-25.50	1280	1540
	-26.00	1370	1660
	-26.50	1620	1950
	-27.00	1680	1980
	-27.50	1700	2040
	-28.00	1780	2130
S203	-23.50	710	890
	-24.00	900	1090
	-24.50	1000	1220
	-25.00	1130	1360
	-25.50	1210	1450
	-26.00	1330	1580
	-26.50	1400	1640
	-27.00	1400	1650
	-27.50	1360	1650
	-28.00	1380	1660
S204	-23.50	540	670
	-24.00	600	740
	-24.50	640	810
	-25.00	920	1140
	-25.50	1150	1390
	-26.00	1500	1720
	-26.50	1530	1840
	-27.00	1590	1920
	-27.50	1660	2000
	-28.00	1740	2090
S205	-22.00	420	520
	-22.50	420	550
	-23.00	420	550
	-23.50	690	860
	-24.00	840	1040
	-24.50	1040	1270
	-25.00	1240	1490
	-25.50	1340	1620
	-26.00	1440	1740

Sondering [nr.]	Paalpuntniveau [t.o.v. NAP]	Rekenw. netto draagkracht Rc;d;netto [kN]	
		410/500 mm	460/560 mm
	-26.50	1500	1800
	-27.00	1660	1980
	-27.50	1780	2150
	-28.00	1910	2310
S206	-22.00	510	620
	-22.50	550	680
	-23.00	540	670
	-23.50	750	930
	-24.00	830	1030
	-24.50	900	1100
	-25.00	1090	1370
	-25.50	1230	1500
	-26.00	1320	1590
	-26.50	1340	1610
	-27.00	1380	1660
	-27.50	1540	1850
	-28.00	1590	1910
S207	-23.00	560	690
	-23.50	620	770
	-24.00	660	810
	-24.50	770	930
	-25.00	880	1090
	-25.50	1070	1290
	-26.00	1220	1470
	-26.50	1310	1570
	-27.00	1350	1620
	-27.50	1560	1890
	-28.00	1900	2320
101	-20.50	500	640
	-21.00	550	640
	-21.50	550	600
	-22.00	550	600
	-22.50	500	620
	-23.00	550	680
	-23.50	550	680
	-24.00	550	680
	-24.50	690	860
	-25.00	840	1020
	-25.50	1020	1270
	-26.00	1140	1360
	-26.50	1150	1360
	-27.00	1150	1360
	-27.50	1150	1360
	-28.00	1180	1390

Sondering [nr.]	Paalpuntniveau [t.o.v. NAP]	Rekenw. netto draagkracht Rc;d;netto [kN]	
		410/500 mm	460/560 mm
102	-22.50	330	410
	-23.00	330	410
	-23.50	370	450
	-24.00	390	470
	-24.50	390	470
	-25.00	510	620
	-25.50	530	650
	-26.00	530	650
	-26.50	710	860
	-27.00	850	1040
	-27.50	1130	1390
	-28.00	1490	--
104	-20.00	560	640
	-20.50	560	700
	-21.00	630	760
	-21.50	630	760
	-22.00	660	810
	-22.50	690	860
	-23.00	720	880
	-23.50	740	930
	-24.00	1090	1370
	-24.50	1230	1500
	-25.00	1260	1530
	-25.50	1380	1670
	-26.00	1680	2030
	-26.50	1790	2160
	-27.00	--	--

-- sondeerdiepte niet toereikend voor berekening draagvermogen op dit niveau.