



efectis
nederland

Declaration of test results

2014-Efectis-R0198-D[Rev.1]

Efectis Nederland BV hereby declares that the products

- FALK ROOF 1000 TR EKO B
- FALK ROOF 1000 GL EKO B

Thickness range:

PIR core: 30 - 60 mm; Total product: 65 - 100 mm

Including steel corner profiles, dimensions 50 x 50 x 1,5 mm,
to be used in corner junctions between cut panels

has been tested by Efectis Nederland BV according to:

EN 13823:2010

“Reaction to fire tests for building products - Building products excluding floorings exposed to the thermal attack by a single burning item.”

EN 11925-2:2010

“Reaction to fire tests.

Ignitability of products subjected to direct impingement of flame.

Part 2: Single-flame source test”

According to the European fire classification standard EN 13501-1:2007+A1:2009
the product has been classified as:

B - s2, d0

The complete details of the test performed and the results are recorded in the
Efectis test report 2014-Efectis-R0198a/b.

This declaration is valid until:

April 2019

This declaration is issued to:

Place and date:

Rijswijk (NL), April 29, 2014

On behalf of Efectis Nederland BV:

Falk Bouwsystemen B.V.
Neonstraat 23
6718 WX EDE (Gld)
The Netherlands

C.C.M. Steinhage B.Sc.
Project leader reaction to fire