

Daglicht toetreding.
Werk: 16-79 Kuinderma, Zelhem.

Ruimte: Verblijfsgebied 1.	Merk;	Ad	Cb	Cu	Ae	
110,0 m2 x 10 %					11,090	
Woonkamer keuken:						
Zijgevel, 2 x 0,46 m2	A	0,920	1,00	1	0,920	
Achtergevel, 2 x 0,94 m2	B	1,880	1,00	1	1,880	
grote pui	C	5,520	1,00	1	5,520	
raam 2 stuks a 0,27 m2	D	0,540	1,00	1	0,540	
Dakvensters 3 stuks SK06	SK06	2,820	0,69	1	1,946	
Studeerkamer						
Zijgevel, 1 x 0,86 m2	A	0,860	1,00	1	0,860	
- min eis 0,5 m2.					-	
Totaal aanwezig					11,666	Voldoet.

Ruimte: Verblijfsgebied 2.	Merk;	Ad	Cb	Cu	Ae	
32,4 m2 x 10 %					3,240	
Slaapkamer 1-2						
Kozijn merk	E	0,590	1,00	1	0,590	
Dakvensters 2 stuks SK06	SK06	1,880	1,00	1	1,880	
Slaapkamer 1-3						
Dakvensters 1 stuks SK06	SK06	0,940	1,00	1	0,940	
					-	
Totaal aanwezig					3,410	Voldoet.

Ruimte: Verblijfsgebied 3.	Merk;	Ad	Cb	Cu	Ae	
9,7 m2 x 10 %					0,970	
Slaapkamer 1-4						
Dakvensters 2 stuks MK06	MK06	1,180	1,00	1	1,180	
					-	
Totaal aanwezig					1,180	Voldoet

Zutphen, 2-10-16. Versie 1.